



PANEL REINFORCEMENT TYPE-PW-1 (NTS)
PANEL THICKNESS AS NOTED
2PP-28 REINFORCEMENT

MANUFACTURE

SETUP:

BED No:

CAST:

BUILT BY:

PREPPED BY:

QA'D BY:

HARDWARE

OFF

M20 N.F. [FIXING]
REID FE20095

9

M20 F.F. [FIXING]
REID FE20095

4

M20 Double [FIXING]
REID FE20095

M20 N.F. [PROP]

2

M20 F.F. [PROP]

M16 N.F. [FIXING]

M16 F.F. [FIXING]

M20 EDGE
FERRULE

CAST-INS

OFF

7t LIFTER EDGE
REID SJS

6

GROUT TUBE
DOWN.

GROUT TUBE
UP.

3

MISCELLANEOUS

PANEL I.D PLATE

C.O.G.
LIFTING CENTROID X

EXPOSED EDGE

Client: AMARCOM GROUP PTY LTD



AMARCOM

Group Pty Ltd
PRECAST PANEL DIVISION.
18-20 Lucca RD, Wyong, NSW, 2259.
PH:02 4352 2468 FAX: 02 4353 1255.

AREA (m2)

17.7

THICKNESS

150

VOL. (m3)

2.7

ConcRete(MPa)

40 MPa

WT (T)

6.63

C of GRAVITY

X 1337

REO.

AS SHOWN 30 COVER

Y 3287

Project:

PROPOSED DEVELOPMENT

AT 43 ACCOLADE AVE. MORRISSET NSW 2264

Prepared By:

WFJ ENGINEERING Co. PTY LTD

Checked

ABN-33 078 373 985

Project No.

DWG / PANEL No.

3576

2PP-28

Rev.

02