# Orion Data Hall: UPS System

*Sample document for a software demo. Fictional project.*

## *1. Scope*

Furnish one UPS system for a fictional AI data hall.

## *2. Ratings*

The UPS shall be rated 1.5 MW at 480 V and 60 Hz. Battery runtime shall be 10 minutes at full load. Efficiency shall be 97%.

## *3. Construction*

The battery type shall be lithium-ion. A maintenance bypass is required. Hot-swappable modules are preferred. The system shall comply with UL 1778. The location is indoor.

## *4. Delivery and budget*

Delivery shall be within 32 weeks. The budget for the UPS system is $700,000.