Cedar Ridge Data Hall: 12.47 kV Outdoor Switchgear Data Sheet

Sample document for a software demo. Fictional project.

1. Scope

Furnish one outdoor switchgear lineup for a fictional 12.47 kV campus feeder.

2. Required ratings

Parameter	Requirement
Rated maximum voltage	15 kV
BIL	95 kV
Main bus	2,000 A
Short-circuit rating	31.5 kA
Frequency	60 Hz
Control voltage	125 VDC
Enclosure	NEMA 3R
Breaker type	Vacuum
Standard	IEEE C37.20.2

3. Other

All items in the table are required. Remote racking shall be provided. Infrared windows are preferred. Delivery shall be within 40 weeks. Maximum site altitude is 800 m.