Harbor Colo: Low-Voltage Power Distribution Switchgear

Sample document for a software demo. Fictional project.

A. General

This document describes the 480 V service switchgear for a fictional colocation site. Mechanical work is not included.

B. Ratings

System voltage shall be 480 V, three phase, 60 Hz. Main bus: 4,000 A continuous, tin-plated copper. Short-circuit rating must be 85 kA. Control voltage must be 125 VDC.

C. Requirements

Assemblies shall be listed to UL 1558 and comply with IEEE C37.20.1. Power circuit breakers shall be air type with drawout breakers. Zone selective interlocking shall be provided. An arc flash maintenance mode shall be provided. The enclosure shall be NEMA 1. Bottom cable entry is required.

D. Site and schedule

Maximum ambient temperature: 40 C. Site altitude: 250 m. Equipment must ship within 34 weeks.