Atlas AI Hall: Server Racks

Sample document for a software demo. Fictional project.

1. Scope

Furnish server racks for high-density AI systems at a fictional data hall.

2. Requirements

Racks shall be 48U high and 600 mm wide. Each rack shall support 100 kW. Static load shall be 3,300 lb. Cooling shall be direct-to-chip. Racks shall comply with EIA-310. Racks shall be seismic certified.

3. Delivery

Delivery shall be within 16 weeks.