Orion Data Hall: UPS System

Sample document for a software demo. Fictional project.

1. Scope

Furnish one UPS system for a fictional AI data hall.

2. Ratings

The UPS shall be rated 1.5 MW at 480 V and 60 Hz. Battery runtime shall be 10 minutes at full load. Efficiency shall be 97%.

3. Construction

The battery type shall be lithium-ion. A maintenance bypass is required. Hot-swappable modules are preferred. The system shall comply with UL 1778. The location is indoor.

4. Delivery

Delivery shall be within 32 weeks.