# ~ Multi-Axis Load Cell Calibration Summary~

260A11/FCS-DN	Customer:	
16936	P.O. Number:	
Charge® 3-Component Force Sensor		
PCB Piezotronics, Inc.	Method:	Back to Back Comparison (Test Procedure AT501-3)
	16936	16936 P.O. Number:

## Calibration Data

Temperature: 73 °F = 23 °C Humidity: 44 %

	Γ	X	Y	Z
Ŧ	(lbs.)	225	225	225
Input:	(N)	1001	1001	1001
Sensitivity:	(pC/lb)	34.19	34.53	15.54
	(pC/N)	7.685	7.763	3.493
Linearity:	(% FS)	0.4	0.3	0.1
Capacitance:	(pF)	18.6	18.6	18.4

# Cross Talk Percentage

Cross Talk	%
X to Y	0.20
Y to X	2.34
X to Z	1.45
Y to Z	2.05
Z to X	1.71
Z to Y	0.19

## Condition of Unit

As Found: _	In tolerance
As Left:	In tolerance

#### Notes

- 1. Station #24 Sensivitity at 6744 lb is 17.30 pC/lb (30 kN is 3.89 pC/N)
- 2. This sensor is calbrated with a 081A70 beryllium copper mounting stud.
- 3. The sensor is preloaded to 5000 lbs. (22.24 kN) prior to calibration.
- 4. Calibration is N.I.S.T. Traceable thru Project # TA333
- 5. This certificate shall not be reproduced, except in full, without written approval from PCB Piezotronics, Inc.
- 6. Calibration is performed in compliance with ISO 9001, ISO 10012-1, ANSI/NCSL Z540-1-1994 and ISO 17025.
- 7. See Manufacturer's Specification Sheet for a detailed listing of performance specifications.
- 8. Measurement uncertainty (95% confidence level with a coverage factor of 2) is +/-1%.

Technician:	Fran Coleman	G-	Date:	1/19/2018
recinician.	i ian Coloman	F	Daic.	1/1//2010





3425 Walden Avenue Depew, New York 14043

TEL: 888-684-0013

FAX: 716-685-3886

www.pcb.com

# **CALIBRATION CERTIFICATE**

Model: Serial #: 260A11/FCS-DN

16936 X - AXIS

Description: Type:

Force Sensor

Charge

Capacitance:

18.6 pF

Date: 1/19/2018

By: Fran Coleman, Cal. Tech. Station: 0-1,000 lb. Load Cell (Test Procedure AT501-3)

Sensitivity\*:

34.19 pC/LBF

7.685 pC/N

Temp: 73 deg F [23deg C] Humidity: 44 %

Linearity\*: Uncertainty\*\*: 0.4% FS +/- 1 %

Cert #: 685672

\* Zero based, least-squares straight line.


\*\* Measurement uncertainty represented using a coverage factor of k=2 which provides a level of confidence of approximately 95 %.

Condition of Unit:

As Found:

In tolerance

As Left: In tolerance



#### **TEST DATA**

INPUT	OUTPUT
(LBF)	(pC)
100	3437
200	6870
300	10296
400	13702
500	17029

#### Notes:

- 1 Station # 24
- 2 The sensor is preloaded to 5000 lbs. prior to calibration. The preload is applied to fixtures that do not shunt forces through the mounting stud.
- 3 Calibration is traceable to NIST and is accredited to ISO 17025 and ANSI/NCSL Z540.3.
- 4 NIST traceability through PCB control # TA333.
- 5 This certificate may not be reproduced, except in full, without written approval from PCB Piezotronics, Inc.





Tel: 716-684-0001 Fax: 716-684-0987 Email: sales@pcb.com 3425 Walden Avenue, Depew NY 14043

Page 1 of 1

# **CALIBRATION CERTIFICATE**

Model: Serial #: 260A11/FCS-DN

Description:

16936 Y - AXIS Force Sensor

Type:

Charge

Capacitance:

18.6 pF

Date: 1/19/2018

By: Fran Coleman, Cal. Tech.  ${\cal H}$ 

Station: 0-1,000 lb. Load Cell (Test Procedure AT501-3)

Temp: 73 deg F [23deg C]

Humidity: 44 %

Cert #: 685674

Sensitivity\*:

34.53 pC/LBF

7.763 pC/N

Linearity\*: Uncertainty\*\*: 0.3% FS +/- 1%

\* Zero based, least-squares straight line.


\*\* Measurement uncertainty represented using a coverage factor of k=2 which provides a level of confidence of approximately 95 %.

Condition of Unit:

As Found: As Left:

In tolerance

In tolerance



#### **TEST DATA**

INPUT (LBF)	OUTPUT (pC)
100	3472
200	6941
300	10398
400	13817
500	17219

#### Notes:

- 2 The sensor is preloaded to 5000 lbs. prior to calibration. The preload is applied to fixtures that do not shunt forces through the mounting stud.
- 3 Calibration is traceable to NIST and is accredited to ISO 17025 and ANSI/NCSL Z540.3.
- 4 NIST traceability through PCB control # TA333.
- 5 This certificate may not be reproduced, except in full, without written approval from PCB Piezotronics, Inc.





Page 1 of 1

Tel: 716-684-0001 Fax: 716-684-0987 Email: sales@pcb.com 3425 Walden Avenue, Depew NY 14043

## **CALIBRATION CERTIFICATE**

Model:

260A11/FCS-DN

Serial #:

16936 Z - AXIS

Description:

Type: Sensitivity\*: Force Sensor

Charge 15.54 pC/LBF

3.493 pC/N

Capacitance:

18.4 pF

Date: 1/19/2018

By: Fran Coleman, Cal. Tech. FC Station: 0-1,000 lb. Load Cell (Test Procedure AT501-3)

Temp: 73 deg F [23deg C]

Humidity: 44 %

Cert #: 685676

Linearity\*: Uncertainty\*\*: 0.1% FS

+/- 1 %


\* Zero based, least-squares straight line.

\*\* Measurement uncertainty represented using a coverage factor of k=2 which provides a level of confidence of approximately 95 %.

**Condition of Unit:** 

As Found: As Left:

In tolerance In tolerance



#### **TEST DATA**

INPUT	OUTPUT
(LBF)	(pC)
200	3095
400	6192
600	9305
800	12430
1000	15560

#### Notes:

- 1 Station # 24 Sensitivity at 6744 lb is 17.30 pC/lb (30kN is 3.89 pC/N)
- 2 The sensor is preloaded to 5000 lbs. prior to calibration. The preload is applied to fixtures that do not shunt forces through the mounting stud.
- 3 Calibration is traceable to NIST and is accredited to ISO 17025 and ANSI/NCSL Z540.3.
- 4 NIST traceability through PCB control # TA333.
- 5 This certificate may not be reproduced, except in full, without written approval from PCB Piezotronics, Inc.





Page 1 of 1