



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/WZ/2024/ 447

Dated:- 21/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Pioneer Convent Senior Secondary School** Located at **Loknayakpuram, Bakkarwala Road, Bakkarwala, New Delhi-110041**, comprised of Ground + 03 Upper Floors & earlier the School building comprised of Ground and First floor was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/School/WZ/2021/1008 dated 14/12/2021**, owned/occupied by **Pioneer Convent Senior Secondary School** have complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act- 2007 & Rules- 2010 and verified by the officer concerned of Fire Service on 06/05/2024 in the presence of Dr. Parmod Kumar (Administrative Officer) and that the premises/building is fit for occupancy class **"Educational Building" Group B** with effect from 21/05/2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 21/05/2024 at New Delhi by.

(Atul Garg)  
Director

Tel No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Pioneer Convent Senior Secondary School, Loknayakpuram, Bakkarwala Road, Bakkarwala, New Delhi-110041.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.