

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No. F6/DFS/MS/School/SZ/2024/74

Dated: 30/01/2024

FIRE SAFETY CERTIFICATE

Certified that Pioneer Kamal Convent School located at Pioneer Road, Vikas Nagar, Hastsal, New Delhi- 110059, comprised of ground plus three upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2020/SZ/517 dated 26.11.2020. The school building was re-inspected by the officer concerned of this department on 16.01.2024 in presence of Mr. Sh. Parmod Kumar, Manager of the school and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 under Delhi Fire Service Act- 2007 and found that the school building is fit for occupancy class "Educational" with effect from 30/01/2024 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 30/01/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Principal, Pioneer Kamal Convent School located at Pioneer Road, Vikas Nagar, Hastsal, New Delhi- 110059.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.