

	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

Datassist has created and implemented this Disaster Recovery Plan (DRP) to be activated in case of various disaster scenarios in terms of Business Continuity and Information Security.

1. DEFINITION

A disaster can be caused by man or nature and can result in Datassist's IT department being unable to fulfil some or all of its regular roles and responsibilities for a period of time. The data centre defines disasters as follows:

- One or more vital systems are not functional
- The building cannot be used for a long time, but all systems work in it.
- The building exists but not all systems are functional
- Building and all systems are not functional

The following events can lead to a disaster and require this Disaster Recovery document to be activated:

- Fire.
- Flooding
- Pandemic
- Power failure
- War
- Theft
- Terrorist attack
- Ransomware / Virus

2. BASIC ASSUMPTIONS

- a. Datassist will ensure that the system operates as it did before the disaster within a maximum period of one week following the disaster.
- b. The production and test environment are equipped with the same operating system versions, security features and configurations. Datassist IT team has assigned the sustainability and management of these two environments to a dedicated resource.
- c. A supplier called SNC can supply the appropriate server hardware within days. The operating system requires one day to be fully installed.
- d. Back-up resources are available to support the Client payroll process in the event of the absence of the incumbent.

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

 datassist TECH DRIVEN PAYROLL & HR SERVICES	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

Key Datassist / Client Resources

1. The person responsible for decision making within Datassist will be Umut Özbağcı.
(umut.ozbagci@datassist.com.tr)
2. Datassist staff who will be responsible for implementing the BCP / DRP plan will be Alen Ege Erboğa. E-mail and telephone numbers are given below: (alen.erboga@datassist.com)
Office: +90-212-2514550
3. If any BCP / DRP scenario is implemented, the Client's HR Manager will be informed immediately by e-mail or telephone.

Office and Systems Locations

1. Datassist's head office is located at Bankalar C. Bozkurt Han No:3 K:2 Karakoy, Istanbul [Turkey].
2. The main system infrastructure consists of two SNC Ractory Servers - Amd Phenom cpu, 8GB Ram - Debian Stable operating system and they are located at the following address (Co-location centre): Dikilitas M. Eren S. No:26 34349 Beşiktaş, Istanbul [Turkey]
3. The secondary system infrastructure consists of one SNC Ractory Server - P4 3GHz CPU, 2 GB RAM - Debian Stable operating system and they are located at the following address (Co-location Centre) Eskişehir Yolu 9. Km no:264 Söğütözü Ankara (Building next to Ankara National Security Council - 500 metres after crossing Bilkent Bridge on the right)

3. PURPOSE

In the event of a disaster, remember that the Data Centre's first priority is to prevent loss of life. Before any secondary measures are taken, we ensure that all employees and any individual in the organisation is safe and secure.

Once all individuals are deemed safe, the next goal is to provide services as will be to implement the steps in this DRP to quickly restore to work.

- Preventing the loss of the organisation's resources such as hardware, data and physical IT assets
- Minimising IT-related downtime
- Maintaining the business in case of disaster

This DRP document will also detail how this document will be maintained and tested.

4. SCOPE

The Datassist DRP Plan considers all of the following areas:

- Network infrastructure
- Servers Infrastructure
- Telephone System
- Data Storage and Backup Systems

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

- Data Output Devices
- End User Computers
- Enterprise Software Systems
- Database Systems
- IT Documentation

Disaster Recovery Teams and Responsibilities

In the event of a disaster, different groups will be required to assist the IT department's Datassist employees in their efforts to restore normal functionality. Different groups and their responsibilities are as follows:

- Datassist Disaster Recovery Team
- System / Network / Server Team
- Application Team
- Senior Management Team

Datassist Disaster Recovery Team

- Data Centre Recovery Team to oversee the entire disaster recovery process.
- In the event of a disaster, they will be the first team to mobilise. This team disaster and what steps are needed to get the organisation back to business as usual. That should be taken in the event of a disaster.
- This will be the team responsible for all communications during a disaster. In particular, Datassist's communication with employees, customers, vendors and suppliers, banks and, if necessary, the media will be set up.

Roles and Responsibilities

- Activate DRP after Team Leader declares a disaster
- To determine the magnitude and class of the disaster
- Identify which systems and processes are affected by the disaster
- Report the disaster to other disaster rescue teams.
- Determining the first steps to be taken by disaster rescue teams.
- To follow up disaster rescue teams with predetermined expectations and targets
- Keep a record of money spent in disaster recovery
- Ensure that all decisions comply with the DRP and the policies set by Datassist.
- Ensure that the secondary site is ready to restore business operations
- Ensure that the secondary site is fully functional and secure
- Create a detailed report of all steps taken in the disaster recovery process.
- Notify interested parties when the disaster is over and normal business functionality is restored

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

 datassist TECH DRIVEN PAYROLL & HR SERVICES	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

- Once Datassist is back to business as usual, this team will need to summarise all costs and will submit a report to the Disaster Recovery Leader summarising their activities during the disaster.

Contact Information

Person	Role	Mobile Phone
Alen Ege Erboğa	Head of Engineering & Products	0543 330 90 60
Müjde Begüm Köşker	PO	0553 860 93 93
Mine İşçi	Minute Support Team Leader	0555 829 72 04
Mehmet Göksel Gün	Head Of Operational Qualification	0532 391 71 31
Yağmur Teke	Information Security and Risk Management Specialist	0507 821 82 56

System / Network / Server Team

The Network/Server Team will be responsible for assessing damage specific to any network infrastructure to provide data and voice network connectivity, including WAN, LAN and any telephone connections made internally within the organisation as well as telephone and data connectivity with the physical server with the outside world. The infrastructure required to run IT operations and applications in the event of a disaster and during operation. They will be primarily responsible for providing major network/server functionality and may assist other IT DR Teams as required.

Role and Responsibilities

- In the event of a disaster that does not require a transition to standby facilities, the team determines which network services are down at the primary site and which servers are down at the primary site.
- If more than one network service is affected, the team prioritises the recovery of services in the order and with the least business impact.
- If more than one server is affected, the team will prioritise the recovery of servers in the order and with the least commercial impact. Recovery will include the following tasks;
 - Assess the damage to any server
 - Restart and refresh servers if necessary
- In the event of a disaster requiring migration to standby facilities, the team will ensure that all network services will ensure that it is brought online at the facility.

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

 datassist TECH DRIVEN PAYROLL & HR SERVICES	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

Contact Information

Person	Role	Mobile Phone
Cem Balık	VAS Manager	0544 253 09 39
Kayahan Teoman	VAS Officer	0530 943 80 72
Begüm Tuncer	Software Administrator	0533 633 08 52

Implementation Team

- The Applications Team is responsible for ensuring that all business applications are operational at the time of and during a disaster.
- will be responsible for ensuring that it operates as required to fulfil its objectives.
- They will be primarily responsible for ensuring and verifying appropriate application performance; and may assist other IT DR Teams as required.

Roles and Responsibilities

- In the event of a disaster that does not require migration to standby facilities, which facilities are the primary is not running in the facility.
- If more than one application is affected, the team will ensure that the recovery of the applications has the least commercial impact. and prioritizes them in order of priority. Recovery performs the following tasks will be included:
 - Evaluate the impact on application processes
 - Restart applications as needed
 - Patch, recode or rewrite applications as needed
- Keeping secondary servers in standby facilities up to date with application patches ensure that
- Keeping secondary servers in standby facilities up to date with data copies Provide
- Install and apply all tools, software and patches required at the standby facility
- Install and apply all tools, software and patches required at the primary site
- Once Datassist is back to business as usual, this team will summarize any costs and submit a report to the Disaster Recovery Lead outlining their activities during the disaster.

Contact Information

Person	Role	Mobile Phone
Berk Aktaş	Software Team Leader	0537 508 97 85
Recep Kement	Software Team Leader	0537 508 97 85
Merve Halilzade	Software Team Leader	0543 677 73 43

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

 datassist TECH DRIVEN PAYROLL & HR SERVICES	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

Senior Management Team

The Applications Team will ensure that all business applications are up and running during and after a disaster. will be responsible for ensuring that it operates as required to fulfill its objectives. They will be primarily responsible for ensuring and verifying appropriate application performance and they can assist other IT DR Teams as needed.

Roles and Responsibilities

- Ensuring that the Data Centre Recovery Team Leader is responsible assistance in their role
- Assist the Data Centre Recovery Team Leader in their role as required.
- Make decisions that will impact the organisation. This may include decisions related to
- Reconstruction of main facilities
- Reconstruction of data centres
- Major hardware and software investments and upgrades
- Other financial and business decisions

Contact Information

Person	Role	Mobile Phone
Ayşe Nazmiye Uça	Chairman of the Board of Directors	0533 472 02 81
Umut Özbağcı	CEO	0530 248 49 65

Data Backup

- This section describes where all the organisation's data is located and backed up.
- Use this information to locate and restore data in the event of a disaster.
- In this section it is important to explain where the organisation's data is located. All
- discuss the location of organisations' servers, backups and off-site backups and
- list what information is stored in each of them.

NAME	EXPLANATION	FREQUENCY	HOW IT IS DONE AND WHERE THE DATA IS STORED
Hourly	Application data, formulas and Database schema	Every hour	Incremental back-up is performed locally and stored on the back-up server at the centre and on the secondary / secondary system.
Diary	Application data, formulas and Database schema	Every day	The entire database is backed up and stored on the back-up server at the centre and on the secondary system.
When the System Changes	Application data, formulas and Database schema	Necessary	Back-up of the operating system, application server and

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

DATASSIST will undertake to perform a restore test at their premises at least once a year. The restoration of data will be performed by the appropriate IT function in Datassist and payroll functions tested by the payroll group. The results of the tests will be documented.

Communication During Disaster

In the event of a disaster, the Data Center will need to communicate with various parties to communicate the impact on business, surrounding areas and timelines. The Communications Team will be responsible for communicating with all Data Centers' stakeholders.

Communication with Employees

The Communications Team's second priority will be to ensure that the entire company is aware of the disaster. The best and/or most practical way to communicate with all employees will be used, with preference given to the following methods

- Email (via corporate email where this system still works)
- Email (external or personal email)
- Phone for employee home number
- Employee phone number

Employees need to be made aware of the following:

- Edit this list to reflect your organization
- Whether it is safe for them to enter the office
- Where should they go if they cannot come to the office?
- Which services are still available to them
- Expectations of working during a disaster

Communication with Employee Contacts

Contact information is on the workflow tool.

Contact with Customers

Once all of the organization's employees are aware of the disaster, the Communications Team will be responsible for informing customers of the disaster and its impact on

- Expected impact on service offerings
- Expected impact on delivery schedules
- Expected impact on the security of customer information
- Expected timelines

Communication with Suppliers

Once all organization employees are aware of the disaster, the Communications Team will be responsible for communicating with suppliers about the disaster and its impact on

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

 datassist TECH DRIVEN PAYROLL & HR SERVICES	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

- Adjustments to service requirements
- Adjustments to delivery locations
- Adjustments to contact details
- Expected timelines

First, key vendors will be notified of the disaster situation. Key vendors will first be emailed and then called to ensure that the message is communicated. All other vendors will be contacted only after all key vendors have been contacted.

Activating the Disaster Recovery Plan

If a disaster occurs in the Data Center, the first priority is to ensure that all employees are safe and accounted for. After that, steps should be taken to mitigate further damage to the facility and reduce the impact of the disaster on the organization.

Regardless of the category into which the disaster falls, dealing with a disaster can be broken down into the following steps:

1. Disaster detection and declaration
2. DR Site Health Check
3. DRP activation
4. Reporting a disaster
5. Current assessment and prevention of further damage
6. Standby facility activation
7. Set up IT operations
8. Repair and reconstruction of the primary facility

DR Site Health Check

The DR Site in the following location will be checked by the network and system teams for health check. If there is a problem, the problem is solved.

Eskişehir Yolu 9. Km no:264 Söğütözü Ankara (next to Ankara National Security Board building - 500 m after Bilkent Korusu on the right.

DRP Activation

When the Disaster Recovery Leadership officially declares the occurrence of an emergency, it will trigger the Disaster Recovery Call Tree and initiate the activation of the DRP. The following information will be provided as and when required to be passed on during the Disaster Recovery Leader's interviews and subsequent discussions:

- It was a disaster
- Nature of the disaster (if known)
- Initial estimate of the magnitude of the disaster (if known)
- Initial estimate of the impact of the disaster (if known)
- First estimate of the expected duration of the disaster (if known)

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

- Actions taken up to this point
- What to do before the Disaster Recovery Team Leader meeting
- Scheduled meeting place for the meeting of Disaster Rescue Team Candidates
- Scheduled meeting time for Disaster Rescue Team Candidates' meeting
- Other relevant information

Assessing the Disaster and Preventing Further Damage

Before any employee working from a Data Center can enter the primary facility after a disaster, the appropriate authorities must first ensure that the facilities are safe to enter. The Facilities Team will be the first team to be allowed to inspect the primary facilities once they are deemed safe. Once the Facilities Team has completed their inspection of the building and sent their report to the Disaster Recovery Leader, the Disaster Management, Networks, Servers and Operations Teams will be allowed to inspect the building. All teams will be required to create an initial report on the damage and provide it to the Disaster Recovery Lead within one week of the initial disaster. During each team's inspection of their respective areas, they should assess areas where further damage could have been prevented and utilize the tools necessary to protect Datassist's assets. Repairs or preventive measures necessary to protect the facilities must be taken; these costs must first be approved by the Disaster Recovery Team Leader.

Standby Facility Activation

Standby Facility, the Disaster Recovery Leader will ensure that the nature of the disaster does not interfere with normal business operations. is such that it is not sufficiently functional or operational to sustain once it has been determined.

Once this determination has been made, the Facilities Team will be deployed to restore the Standby Facility to an operational state. The Disaster Recovery Leader will then convene various Disaster Recovery Team Leaders at the Standby Facility to discuss next steps. and the next steps to be taken. These next steps will include:

1. Identification of affected systems
2. Criticality ranking of affected systems
3. Recovery measures required for high critical systems
4. Determination of responsibilities for critical systems
5. Program for recovery of high critical systems
6. Recovery measures required for medium critical systems
7. Determination of responsibilities for moderately critical systems
8. Program for recovery of moderately critical systems
9. Recovery measures required for low critical systems
10. Assigning responsibilities for the recovery of low critical systems
11. Program for recovery of low critical systems
12. Identification of plant tasks pending/required at the Standby Facility
13. Identification of pending/required processing tasks in the Waiting Facility

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

14. Identification of pending/requested communication tasks at the Standby Facility

15. Identification of pending/desired facility tasks at the Primary Facility

16. Identification of other pending/requested tasks at the Primary Facility

17. Determination of other actions to be taken

During Standby Facility activation, the Facilities, Networks, Servers, Applications and Operations teams need to ensure that their responsibilities as described in the “Roles and Responsibilities of the Datassist Disaster Recovery Team” section of this document are carried out quickly and efficiently. To negatively impact other teams.

Restoring IT Functionality

If a disaster actually occurs and the Data Center needs to use this plan, this section will be referred to frequently as it will contain all the information describing how to recover the Data Center's information system.

This section will contain all the information needed to return the organization to regular functionality after a disaster has occurred. It is important to include all Standard Operating Procedures documents, workbooks, network diagrams, software format information, etc. in this section.

Please list all IT Systems in your organization in order of importance. Then list the components of each system that need to be brought back online in the event of a disaster. Add or delete rows as needed in the table below.

Rank IT System Components (in order of importance)

Minute 1 Application Server

Minute 2 Database

3. VDI Citrix Servers

Minute 4 SFTP Servers

Test and Maintenance Plan

While efforts are initially made to make this DRP as complete and accurate as possible, it is impossible to address all possible issues at any given time. In addition, the Disaster Recovery needs of the business will change over time. As a result of these two factors, this plan will need to be tested periodically to discover errors and shortcomings and will need to be maintained to address them.

Care

The DRP will be updated annually or any time a major system update or upgrade is made, whichever is more frequent. The Datassist Disaster Recovery Team Leader will be responsible for updating the entire document and will be allowed to request information and updates from other employees and departments in the organization to complete this task.

Maintenance of the plan will include (but not limited to) the following:

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

1. Ensuring all team rosters are up to date
2. Reviewing the plan to ensure that all instructions are still relevant to the organization.
3. Any major changes and revisions to the plan to reflect organizational changes, modifications and objectives
4. Ensure that the plan meets the requirements set out in the new laws
5. Other organization-specific care goals

During maintenance periods, all changes in the Datassist Disaster Recovery Team must be taken into account. If any member of any Datassist Disaster Recovery Team no longer wishes to work with the company, it is the responsibility of the Datassist Disaster Recovery Team Leader to appoint a new team member.

Test

The data specialist is committed to ensuring that this DRP is functional. The DRP should be tested every year to ensure that it is still effective. Testing of the plan will be carried out as follows: Choose which methods your organization will use to test the DRP

1. **Walkthrough:** Team members verbally walk through specific steps outlined in the plan to confirm effectiveness, identify gaps, bottlenecks or other weaknesses. This test provides an opportunity to review a plan with a wider subset of people, allowing the DRP project manager to benefit from a correspondingly increased pool of knowledge and experience. Staff should be familiar with procedures, equipment and off-site facilities (if required).
2. **Simulations:** A disaster is simulated so that normal operations are not interrupted. Hardware, software, personnel, communications, procedures, consumables and forms, documentation, transportation, utilities and alternative site processing should be thoroughly tested in a simulation test. However, validated checklists can provide a reasonable level of assurance for most of these scenarios. Carefully analyze the output of previous tests before the proposed simulation to ensure that lessons learned in earlier stages of the cycle are applied.
3. **Parallel Testing:** Parallel testing can be done with checklist testing or simulation testing. In this scenario, historical transactions, such as previous business day transactions, are processed against the previous day's backup files at the emergency processing site or hot site. All reports generated at the alternate site for the current operating date must be identical to the reports generated at the alternate processing site.
4. **Total Disruption Test:** A Total Disruption Test enables total DRP. The test is likely to be expensive and disrupt normal operations and should therefore be handled with care. The importance of due diligence over the previous DRP phases cannot be overstated. Gaps in the DRP identified during the testing phase will be addressed by the Disaster Recovery Lead and the resources they will require.

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

	DISASTER RECOVERY PLAN (DRP)				
	Document Code	Release date	Revision No	Revision Date	Page No
	PNL.09	10.10.2019	11	21.07.2026	1/14

BCP / DRP Scenarios Table

Type of Problem	Name of the Problem	Description	DRP Procedure
Hardware	Component Failure	Failure of some hardware components for which spare parts are available in the Production or Test machine	A backup of the most recent data restored on the secondary system takes control and the main system is repaired as soon as possible (see Datassist detailed procedures)
Hardware	Component Failure	Failure of some hardware components for which spare parts are not available within the Production or Test machine	A backup of the most recent data restored in the secondary system takes control and the main system is repaired upon receipt of the spare parts (a contract is concluded with the supplier)
Hardware	General Failure	Complete failure of the main system beyond repair	The secondary system takes over and the main system is replaced within 10 days.
Hardware	General Failure	Complete and irreparable failure of the primary and secondary / secondary system	If both servers are completely down and cannot be repaired, Datassist purchases a new server from SNC or another manufacturer. Return to normal operation is expected in 7-10 days.
Software	An important bug in the software version	An error in an already online application	While Datassist programmers are focused on the problem, the latest verified software version is restored.
Software	An important failure in payroll data	Data in customer databases appear corrupted	The most recent data backup tapes are restored. Lost data and inputs are traced until a complete alignment is reached.
Software	Significant failure in the DATASSIST operating system	The operating system cannot be repaired	A backup of the most recent data restored on the secondary system takes control and the main system is repaired as soon as possible (see Datassist detailed procedures)
Power Supply	No power supply at all	Failure of power supply systems in one of the colocation center buildings	If the main system fails, the secondary system takes over until the power supply is restored. NOTE: The secondary system is located in a separate location in Ankara.
Power Supply	No power supply at all	Failure of power supply systems in Datassist building	Payroll systems are not affected as the Primary and Secondary systems are not located at Datassist head office. In this case, access to the system is via the internet and dial-up connection or VPN.
Disaster	Natural disaster or caused disaster	Fire, flood, earthquake, war, terrorist acts, damage	In the event of a natural disaster, the secondary system takes over. The secondary system is located in Ankara, about 600 km away from the

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

DISASTER RECOVERY PLAN (DRP)

Document Code	Release date	Revision No	Revision Date	Page No
PNL.09	10.10.2019	11	21.07.2026	1/14

			main location. And it always uses the latest version of the payroll application and the latest updated database (see back-up procedure)
Disaster	Access to the building	transmitter actions etc.	The data required for payroll calculation will be requested from the Client in hard copy or by encrypted e-mail using appropriate mass media. The payroll system can be run from any location with an internet connection. Only lost data will be e-mailed from the Client to the Datassist Representative.
Internet	Main connection failure	Datassist's building is never accessible	Datassist will return to the second internet line.
Security	Absence of persons	Datassist's Doruk.Net DSL Connection failure	Datassist has two backup staff for the Client's payroll process. In the event that the first representative is out of the office, the back-up person will take over and keep the Client appropriately informed. Each backup resource has its own system access.

Other System Procedures in Datassist

Type of Procedure	Name	Description	Procedure
Redundancy /redundancy	Secondary System goes online	The main system goes online for any reason	The secondary system periodically checks the main system and its various services. These services need to be offline for a certain period of time.
Redundancy /redundancy	Main System goes online	The disaster is resolved. The system is restored to its previous state.	In case of a crash, the secondary system starts its own services and sends the DNS change request signal and announces itself.
Security	Penetration	Hacker, security breaker, etc. activity	Servers are placed behind a Juniper SSG Firewall. The rules are managed by DorukNet's professional security experts.
Security	Power ID usage	Power ID user accesses Servers.	Datassist backups are linked to three related servers that have both two-element and text-controlled logs. In case of any security breach, these logs are investigated and necessary measures are taken.
Security	File transfer	File transfer to Customer via Datassist	All parties have their own PGP accounts to log in and encrypted files to send. Anyone can encrypt a file for the other party and log in with their own key.
Security	Audit	Periodic IT audit	Datassist IT infrastructure is audited quarterly by an independent Security Auditor. With the audit report, necessary arrangements are planned and the appropriate position is taken.

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.

DISASTER RECOVERY PLAN (DRP)

Document Code	Release date	Revision No	Revision Date	Page No
PNL.09	10.10.2019	11	21.07.2026	1/14

DATASSİST BİLGİ TEKNOLOJİLERİ A.Ş.
BANKALAR CAD. BOZKURT HAN NO:3 KAT:1 KARAKÖY - İSTANBUL
Tel: +90 444 4 923 FAX:0212 251 40 22

Preparer	Enforcement Approval
YAĞMUR TEKE IT Quality Management Officer	UMUT ÖZBAĞCI CEO

**Documents that can be seen by all company employees and which should not be seen by outsiders are included in this class.*

***Electronic Copy is an Uncontrolled Document.*

This document is for information only if it is not stamped and initialed from the time it is printed.