



NOTES:

1. All joints must be restrained and must be ductile iron pipe.
2. A mechanical joint isolation valve is required at the hydrant on hydrant runouts greater than 20 feet from center of supply valve to the center of the hydrant.
3. Hydrant sets can be purchased and installed by the City (does not include tap). 727-562-4600.
4. All hydrants must have stainless steel stem.
5. All hydrants must be installed plumb.
6. 4' minimum clearance from nearest obstruction, including back of curb and vehicular travel. 2' minimum clearance from sidewalk.
7. All clearances for Fire Department apparatus must conform with latest NFPA Fire code.
8. See also City of Clearwater's Technical Specification Section IV.

ONLY APPROVED

Kennedy Guardian No. K-81D
 Mueller Super Centurion No. 250
 American Darling B-84-B-5
 AVK-Nostalgic 2780
 EJ Co. Watermaster 5CD250

DATE	REVISION DESCRIPTION	APP

CITY OF CLEARWATER
 ENGINEERING DEPARTMENT
 POTABLE WATER
 DETAILS

TYPICAL FIRE HYDRANT SETTING
 PLAN VIEW

INDEX NO.	PAGE NO.
409	1 OF 3
LATEST REVISION	10/22/2019