



NOTES:

1. Gate Valve shall be open left only.
2. Tracer wires shall be colored Pantone 522c.
3. Use spigot 90° in valve to accommodate 1 larger composite box set to grade and load bearing in traffic areas.
4. See also City of Clearwater's Technical Specification Section IV.

DATE	REVISION DESCRIPTION	APP
------	----------------------	-----

CITY OF CLEARWATER  
ENGINEERING DEPARTMENT  
RECLAIMED WATER  
DETAILS

RECLAIMED 6" BLOWOFF DETAIL

INDEX NO.	PAGE NO.
503	1 OF 2
LATEST REVISION	11/08/2019