



**NOTES:**

1. Subject to City Engineer's approval for use in only unique situation.
2. Flow line (Section A-A) shall have a minimum slope of 0.5%. Any slope less than 0.5% will require prior approval.
3. Concrete shall be 3,000 PSI with fibermesh.
4. Control joints shall be a minimum of 8' and a maximum of 10' apart.
5. Unit cost is in S.Y. unless otherwise instructed.

DATE	REVISION DESCRIPTION	APP

**CITY OF CLEARWATER**  
ENGINEERING DEPARTMENT  
**STREET SECTIONS  
AND DETAILS**

**CONCRETE SWALE DETAIL  
FOR VALLEY GUTTER CURB**

INDEX NO.	PAGE NO.
107	2 OF 2
LATEST REVISION	10/24/2019