



**NOTES:**

1. Saddles are required to all service connections to main.
2. Iron service saddle shall be Ford FC 202 series with stainless steel band and epoxy coated ductile iron body, or approved equal.
5. Taps should be made on a 45° angle from top of pipe. For cover less than 30", City of Clearwater Engineering Department approval is required.
6. For all other taps that can not be done as described above refer to Potable Water Main Service Connection Detail, (Swing Joint Installation).
7. Stiffeners shall be manufactured by Mars Company P.O. Box 830340, Ocala, FL 34483
8. See also City of Clearwater's Technical Specifications Section IV.

DATE	REVISION DESCRIPTION	APP

**CITY OF CLEARWATER**  
ENGINEERING DEPARTMENT  
**RECLAIMED WATER**  
DETAILS

**RESIDENTIAL RECLAIMED**  
**WATER CONNECTION**

INDEX NO.	PAGE NO.
501	2 OF 2
LATEST REVISION	10/21/2019