



NOTES:

1. O S & Y valve handles will be chained and locked by City.
2. Meter sets will be painted after installation by City.
3. Bypass pipe & fittings shall be threaded brass.
4. Gate valve shall be set at water main. For all water meter sets over 20 feet from water main, an additional isolation gate valve shall be installed within 2 feet of the device and all bells must be restrained.
5. All pipes between the water main and owner installed gate valve shall be ductile iron.
6. 3" meter requires 4" tap, DIP service Line and 4" DIP standpipes.
7. Minimum of 3' clearance from back of curb and sidewalk.
8. Minimum of 3' clearance around all sides.
9. No concrete slabs allowed under device.
10. Contractor must purchase meter and backflow sets from the City of Clearwater Customer Service Department (727-562-4600). City will install.
11. For Installation, contractor shall schedule with Clearwater Public Utility Department (727-562-4960 Ext. 7227).
12. See also City of Clearwater's Technical Specification Section IV.

DATE	REVISION DESCRIPTION	APP

CITY OF CLEARWATER
ENGINEERING DEPARTMENT
POTABLE WATER
DETAILS

TYPICAL COMPOUND WATER METER SET
90° RISE
3", 4", 6" & 8" MODELS

INDEX NO.	PAGE NO.
410	1 OF 2
LATEST REVISION	10/21/2019