

**CLEARWATER BEACH MARINA  
ELECTRICAL DISTRIBUTION EVALUATION  
& FEASIBILITY STUDY  
A/E #17039**

**25 CAUSEWAY BLVD  
CLEARWATER BEACH, FLORIDA 33765**

FOR THE

**CITY OF CLEARWATER  
CLEARWATER, FLORIDA**



**DRAFT REPORT  
SEPTEMBER 18, 2018**

PREPARED BY:



**LONG & ASSOCIATES**  
architects | engineers, inc.

4525 SOUTH MANHATTAN AVENUE, TAMPA, FL 33611-2305

AAC001624

WWW.LONGANDASSOCIATES.COM

1828

T: 813.839.0506 F: 813.839.4616

CGC1511025

## **TABLE OF CONTENTS**

- A. INTRODUCTION**
- B. EXECUTIVE SUMMARY**
- C. EVALUATION OF EXISTING POWER DISTRIBUTION SYSTEMS SERVING THE DOCKS**
  - 1. Existing Conditions Survey - West and Main docks
  - 2. Existing Conditions Survey – East Docks
- D. CONCEPTUAL OPTIONS**
  - 1. Install the Main/West dock new power service equipment, service equipment platform and Main Dock power distribution system.
  - 2. Install the West dock new power distribution system. After the new power distribution system is installed, the existing Main/West Dock old power service and power distribution system shall be removed. Option #1 is required to be done first, then Option #2.
  - 3. Install East dock new power service equipment, service equipment platform and East Dock power distribution system. After the new service and power distribution systems are installed, the existing East Dock old service and power distribution systems shall be removed.

These options provide for new dock power services and power distribution systems to be installed in parallel to the existing dock power service and distribution systems. When the new power distribution system(s) are in place, new slip power distribution feeders and pedestals can be installed in group and the old power distribution systems can be removed. This approach minimizes boat slip downtime required to install new power distribution systems and can be phase to block-off a section of boat slips for new power distribution system upgrades as needed.

## **E. CONCLUSIONS**

- 1. Condition of Use
- 2. Opinion of Probable Costs

## **APPENDICES**

- Appendix A Photos**
- Appendix B Bibliography of Reviewed Documents**
- Appendix C Codes and Standards**
- Appendix D Cost Estimate**
- Appendix E Field Survey Drawings**
- Appendix F Electrical Risers & Voltage Drop Calculations**

## A. INTRODUCTION

Long & Associates was retained to provide the City of Clearwater with Field Survey Drawings for the east and west marina boat dock power distribution systems, evaluate existing electrical power system issues and provide a feasibility study of options and probable costs for alternative solutions. The Marina Maintenance Staff have indicated that they are experiencing voltage drop problems in the existing electrical distribution systems serving the boat docks at the Marina. The age and capacity of the existing systems are not keeping up with the demand of modern boats. The scope of services as defined by the following descriptions of project objectives and project deliverables was established in coordination with City staff. Our team of Architectural and Engineering professionals undertook a series of site observation visits and conducted a series of Document reviews and interviews with City staff to assess the existing conditions and identify deficiencies which must be addressed to put the resolve the electrical issues at the boat docks.

## PROJECT OBJECTIVES

1. Generally review and evaluate the existing Clearwater Beach Marina Boat dock power distribution systems and render a third party Professional opinion of the conditions and feasibility study with options to correct the electrical issues, including an opinion of probable costs.
2. Evaluate the possible electrical corrections of the boat dock electrical distribution system 3 possible options
  - a) Install the main/west dock power service, service platform and main dock power distribution system.
  - b) Install the west dock power distribution system.
  - c) Install the east dock power service, service platform and power distribution system.

## PROJECT DELIVERABLE

1. This Final Report includes executive summary, evaluations, and observations, field survey drawings a feasibility study. This includes the written existing conditions evaluation, a Code Review evaluation, and an Opinion of Probable costs.

## **PROJECT TEAM**

Paul Portal, AIA, LEED AP, Architect, Principal

Paul E. Wieczorek, PE, Structural Engineer, Principal

Robert A. Race II, PE Electrical Engineer

## **FORMAT AND PROCESS**

This Final Report is organized into an evaluation section with separate chapters for each discipline involved by floor. Following the evaluation we have included separate chapters to address and highlight specific issues requested by the owner. Conceptual options have been provided to address a staged remodeling of the facility for various tenant use and to evaluate the various portions of the facility that would have to be remodeled to make each portion function and Code compliant. Lastly we have provided an Opinion of Probable Costs based on the project area to be remodeled and average current construction costs presuming 3% inflation for each year hereafter.

The evaluation of the facility was based solely on visual observations by experienced design professionals, a review of available construction documents, and from information obtained through interviews with City personnel. Testing and analysis of materials and methods of construction and operational condition of equipment and systems was not performed within the scope of this project. Information such as dates of original construction and subsequent additions and renovations was taken from best available data from other sources provided by the owner. Recommendations for enhancements to existing facilities are described in broad terms only to establish the general scope of work required to address needs and deficiencies identified through the evaluation process outlined in this report. Detailed work plans and specific design solutions are beyond the scope of this project. The recommendations are provided to assist the City in a cost-benefit analysis of the potential upgrade of the Marina docks.

## **OPINION OF PROBABLE COST**

Our Opinion of Probable Cost is provided to assist the City in financial planning and budgeting necessary to understand the magnitude of effort required to upgrade the existing marina power distribution systems and make them suitable for tenant, private and commercial vessel use. The opinion of probable construction cost stated for each work scope is based on our professional experience in the Tampa Bay construction market and we have provided a range of costs. These figures are expressed in 2018 dollars, and extrapolation will be required for any cost projections in future years based on inflation, market fluctuation and other factors. We have suggested a 3% increase be used for future inflation for each year thereafter.

## **LIMITATIONS OF USE**

This report has been prepared solely for the use of the City of Clearwater as a planning and budgeting tool, and may not contain sufficient or appropriate information for other uses or for the purposes of other parties. In the event any conclusions or recommendations based upon this report are made by others, such conclusions or recommendations cannot be construed to reflect the professional opinions of Long & Associates unless we have been given the opportunity to review and concur with them in writing. We appreciate the opportunity to have provided this Professional Architectural and Engineering service for the City of Clearwater. If you have any questions concerning this report, or if we may be of further assistance, please do not hesitate to contact us at your convenience.

## **B. EXECUTIVE SUMMARY**

Based on our visual observations of this facility, the marina dock power distribution systems need various significant repairs or replacements to correct the low voltage issues and make the systems Code compliant and usable. Many of the Marina power distribution systems components have outlived their useful life span and are in need of replacement or significant upgrades and would have to be upgraded to meet the current FBC, NEC and FEMA requirements including the power distribution equipment and related structural support platform systems for distribution equipment. In addition, the future expansion of the marina docks will need to be considered so that spare capacity can be planned for the new power distribution system design in order to accommodate the anticipated future loads for the dock expansion projects.

This report cannot be considered all inclusive for such an evaluation since the future use is not known. A choice of these systems depends largely on the intended use, longevity and future dock expansion plans.

## **DOCUMENTATION**

The Clearwater Marina is a City Owned facility located on 25 Causeway Blvd in Clearwater Beach, Florida. The site is over 40 years old. A Phase II expansion of the Marina was complete in 1973. A new fueling dispensing system was installed in 1988.

Upon approval and notice to proceed, Long & Associates received documents from the City which were reduced copies of the original construction documents of the subject project. The documents received are listed as follows:

1973 Construction Documents (incomplete) of Clearwater Marina Phase II Expansion

1987 Construction Documents (incomplete) of Clearwater Marina New Fuel Dispensing System

The original scanned documents provided appeared to be incomplete and were largely unreadable as the copies were of poor quality. These documents have been reproduced in the Appendix C accordingly.

## **C. EVALUATION OF EXISTING POWER DISTRIBUTION SYSTEMS SERVING THE DOCKS**

Long & Associates began the on-site field investigation process to observe and document the existing conditions of the Marina power distribution systems. Our team of professionals met with Mr. Mike Macdonald and Patrick Shackton on site for access to the marina facilities. The marina dock power distribution systems were observed by Long & Associates Representatives to document the conditions.

### **EXISTING CONDITIONS SURVEY**

#### **Marina Power Distribution System - West and Main Docks**

The existing west docks and Crabby's Dockside restaurant are served power from an existing pad mounted 300 KVA, 208Y/120 V, three phase, 4 wire Duke Energy Transformer. Reference Enlarged Site Plan on dwg E2.2 in Appendix C for power distribution equipment locations. The transformer has three service laterals. One lateral serves the Crabby's Dockside restaurant, another serves the 400 amp service panelboard "MSP1" and the third lateral serves the 600 amp fused service switch "MSP2". Reference West Dock Electrical Riser on dwg E3.3 in Appendix C for boat dock distribution equipment interconnections. Both services incorporate a Duke Energy meter.

A feeder circuit from service panel "MSP1" serves a feeder tap box "FT1" located on the south end of the west-center main dock. Feeder and branch circuit tap circuit breakers in tap box "FT1" serve feeders and branch circuits that distribute power to multiple vessel power pedestals and other loads on the boat docks (See feeder tap box "FT1" schedule on dwg E3.3, Appendix C, for loads served from the tap box circuit breakers). The slips on the docks consist of private, transient vessels.

A feeder circuit from service switch "MSP2" serves a feeder tap box "FT2". Feeder and branch circuit tap circuit breakers in tap box "FT2" serve feeders and branch circuits that distribute power to multiple vessel power pedestals and other loads on the boat docks (See feeder tap box "FT2" schedule on dwg E3.3, Appendix C, for loads served from the tap box circuit breakers). The slips on the docks consist of Owner metered commercial vessels.

### **Observations:**

Based on conversations with the Staff at the Marina, there is a shore power distribution system low voltage issue. Vessel power distribution systems, in some cases, will not allow connection to shore voltage if shore power voltage is too low. Low shore power voltage conditions also create a higher risk of damage to Vessel electronic systems and can be a liability to the Marina. Some Vessel Owners provide and connect their voltage step-up transformers (see pic #1 in Appendix A) to shore power pedestals in order to increase the shore voltage to allow Vessel power system to operate and reduce potential damage to vessel electronics due to low voltage conditions. In addition, based on estimated load calculations for the existing service and feeder conductors serving the Marinas dock loads, many of the existing service and feeder circuits are overloaded. The circuit overload conditions will contribute to the voltage drop problems (the larger the load is on an undersized circuit, the higher the voltage drop). Reference NEC Article 555.12 "Marina Load Calculations for Service and Feeder Conductors" in Appendix C.

Branch circuits of the voltage class and rating corresponding to the rating of the receptacle must supply each receptacle that supplies shore power to boats per NEC Article 555.19 (A)3. The Code reference requires 240V rated power pedestals to be served supplied from a 240 Volt system. The referenced Code section also explains that supplying 120/240 V 3-wire receptacles from a 120/208V 3-wire supply may

cause overheating or malfunctioning of connected equipment per NEC.

The existing marina power distribution systems and estimated loads were modeled in a software program called Easy Power to estimate voltages at the existing power pedestals in order to evaluate the voltages at the pedestals. (See "West Dock Electrical Riser" in Appendix F). The maximum voltage drop at the power pedestals for 240 Volt connections should be 5% voltage drop or  $240V \times .95 = 228$  Volts. The voltage calculations in the Easy Power model show existing power pedestal voltages substantially lower than 228 Volts. See clouded areas on Risers that show low voltages of 199 V and 186 V.

Part of the existing problem at the marina is that the source system serving the boat docks is 208 Volts systems and should be a 240 V systems. The existing 208V systems are starting-off as lower voltage than allowed by Code (228 Volts – 5% voltage drop max) for power serving 240 V rated vessel power pedestals.

Power distribution equipment appears to be obsolete, not in serviceable condition, located within 100 year FEMA base flood elevation and has inadequate power capacity to serve existing and future marina dock loads, based on current power demand calculation requirement per NEC Article 555 Code requirements for Marinas.

Based on conversations with the Staff at the Marina, there are existing power distribution connections serving the dock loads that are located below the Electrical Data Plane (normal highest high tide elevation) as defined in NEC 555.9 for fixed piers (reference NEC 555.9 in Appendix C). As a result, the AHJ has required two tide level markings on one of the Main Pier pilings to mark maximum tide levels, one for the east docks and one for the west docks (reference pic #6 in Addendum A). When tide level reaches the lower mark, the Marina is required to Shut-off power serving the west docks and when the tide level reaches the upper mark, the Marina is required to shut-off power to the east docks. The Marina Staff indicates that some years, these high tide levels occurs several times a year and causes major power disruptions and issues with the Marina Transient, Private and Commercial Slip Tenants. Per FEMA Requirements (Reference FEMA Construction Principles and Practices in Appendix C), Electrical utilities and equipment must be located (elevated) and designed to prevent flood waters from entering and accumulating in electrical components during flooding. In the Coastal Zone where the Clearwater Beach Marina is located, the flood water elevation height is based on the FEMA 100 year Base Flood Elevation

(BFE) for the area, which is approximately 12 feet. As a result, the new power service equipment serving the new docks will need to be mounted on a platform that is above the BFE. The existing seawall elevation at the west docks is approximate 2 feet and the main dock seawall elevation is approximately 3'. Reference back of Appendix E for SWFWMD Satellite Mapping and GIS Section of the Clearwater Beach Marina areas showing land mass elevations (yellow lines and red elevation numbers).

The existing service entrance panelboards and subpanels do not have a TVSS (transient voltage surge suppressor) or SPD (surge protective device) units. Most of the existing power distribution system equipment is in extremely poor condition and no longer serviceable. The existing power distribution service panels, panelboards, panelboard directory cards, meter centers, tap boxes, disconnects, slip power pedestals, and power distribution equipment are not labeled and Arc flash labels are not provided in accordance with NEC requirements. Electronic circuit breakers should be field tested and calibration verified. Thermography of circuit breakers and terminations is recommended. All abandoned equipment, wire and conduits shall be removed from distribution panels, tap boxes and cabinets. All feeder and branch circuit breakers in Tap boxes shall be labeled. Many panels are not rated for marine environment applications and have severe rust and are not safe. Reference pictures in Appendix A: pic #2 – Service panel "MSP1" and pic #3 – Service breaker "MSP2". Conduit Supports for many feeder conduits are missing and conduit is not adequately supported, reference pictures in Appendix A, pic #4. Feeder tap boxes had numerous taps, some illegal taps, not adequate conductor bending space and breaker labels missing, reference Appendix A, pic #5 and #6.

#### **Marina Power Distribution System - East Docks**

The existing east docks are served power from an existing pad mounted 75 KVA, 208Y/120 V, three phase, 4 wire Duke Energy Transformer. Reference Enlarged Site Plan on dwg E2.4 in Appendix C for power distribution equipment locations. The transformer serves three service laterals; one feeds a 400 amp service panelboard "MSP3", another lateral feeds a 600 main circuit breaker "MSP4" in Meter Center "MC" and the third lateral serves the dumpster panel "DPD". Reference East Dock Electrical Riser on dwg E3.3 in Appendix C for boat dock distribution equipment interconnections. CT's are provided on the Duke transformer secondary bus and the CT's are circuited to a Duke demand meter mounted next to the transformer.

"MSP4" service disconnect serves meter center "MC" at the existing electrical service stanchion. Meter Center "MC" feeder circuit breakers serve feeders that distribute power to power pedestals/disconnect switches for Commercial Slips, bait house subpanels, admin office/bathroom subpanel and other loads on the boat docks (See Riser #2/Dwg E3.3 in Appendix C for loads served from meter center "MC"). The slips near the concrete seawalls consist of Owner metered commercial vessels.

Feeder circuits from service panelboard "MSP3" distribute power to vessel power pedestals on the docks, Starship II disconnect/loadcenter, fuel dock house subpanel and other branch circuit loads (See Riser #2/Dwg E3.3 in Appendix C for loads served from service panel "MSP4").

#### **Observations:**

Based on conversations with the Staff at the Marina, there is a shore power distribution system low voltage issue. Vessel power distribution systems, in some cases, will not allow connection to shore voltage if shore power voltage is too low. Low shore power voltage conditions also create a higher risk of damage to Vessel electronic systems and can be a liability to the Marina. Some Vessel Owners provide and connect their voltage step-up transformers (see pic #1 in Appendix A) to shore power pedestals in order to increase the shore voltage to allow Vessel power system to operate and reduce potential damage to vessel electronics due to low voltage conditions. In addition, based on estimated load calculations for the existing service and feeder conductors serving the Marinas dock loads, many of the existing service and feeder circuits are overloaded. The circuit overload conditions will contribute to the voltage drop problems (the larger the load is on an undersized circuit, the higher the voltage drop). Reference NEC Article 555.12 "Marina Load Calculations for Service and Feeder Conductors" in Appendix C.

The existing marina power distribution systems and estimated loads were modeled in a software program called Easy Power to estimate voltages at the existing power pedestals in order to evaluate the voltages at the pedestals. (See "East Dock Electrical Riser" in Appendix F). The maximum voltage drop at the power pedestals for 240 Volt connections should be 5% voltage drop or  $240V \times .95 = 228$  Volts. The voltage calculations in the Easy Power model show existing power pedestal voltages substantially lower than 228 Volts. See clouded areas on Risers that show low voltages of 189 V and 193 V.

Part of the existing problem at the marina is that the source system serving the boat docks are 208 Volts systems and should be a 240 V systems. The existing 208V systems are starting-off as lower voltage than allowed by Code (228 Volts – 5% voltage drop max) for power serving 240 V rated vessel power pedestals.

Power distribution equipment appears to be obsolete, not in serviceable condition, located within 100 year FEMA base flood elevation and has inadequate power capacity to serve existing and future marina dock loads, based on current power demand calculation requirement per NEC Article 555 Code requirements for Marinas.

Branch circuits of the voltage class and rating corresponding to the rating of the receptacle must supply each receptacle that supplies shore power to boats per NEC Article 555.19 (A)(3). The Code reference requires 240V rated power pedestals to be served supplied from 240 Volt system. The referenced Code section also explains that supplying 120/240 V 3-wire receptacles from a 120/208V 3-wire supply may cause overheating or malfunctioning of connected equipment per NEC.

The existing service entrance panelboards and subpanels do not have a TVSS (transient voltage surge suppressor) or SPD (surge protective device) units. Most of the existing power distribution system equipment is in extremely poor condition and no longer serviceable. The existing power distribution service panels, panelboards, panelboard directory cards, meter centers, disconnects, slip power pedestals, and power distribution equipment are not labeled and Arc flash labels are not provided in accordance with NEC requirements. Electronic circuit breakers should be field tested and calibration verified. Thermography of circuit breakers and terminations is recommended. All abandoned equipment, wire and conduits shall be removed from distribution panels, tap boxes and cabinets. All feeder and branch circuit breakers in electrical gear shall be labeled and panelboard directory cards updated with loads served.

#### **CODE COMPLIANCE REVIEW:**

The current Codes applicable at this time are:

2017 Florida Building Code

2017 Florida Energy Conservation Code

2014 National Electric Code

2013 ASHRAE 90.1

Electrical feeders exceed maximum 2% voltage drop and branch circuits exceed maximum 3% voltage drop requirements NEC Articles 210.19 (A) and 215.2(A) and ASHRAE 90.1 -8.4. Existing loads on service and feeder conductors exceed the allowable load demands per NEC 555.12.

Electrical service disconnects are not properly labeled per NEC Article 230.3 (E), power distribution equipment is not labeled per NEC 110.22 and most equipment does not have Code compliant arc flash labels per NEC 110.21. Electrical panels with exposed live buss bars that are accessible from holes in bottom of electrical panels and cabinets (some enclosures have rusted-out bottoms).

#### D. CONCEPTUAL OPTIONS

This report includes a visual observation of the existing marina power distribution systems to determine the feasibility of upgrading the distribution systems. Our opinion of probable costs is based construction costs anticipated for the 2018 Fiscal Year, presuming 3% inflation for each year thereafter.

The first cost option is to review the existing power distribution system serving the west marina docks and determine a relative cost to upgrade the distribution system to correct system voltage drop, power demand and Code deficiencies. This option would include leaving the existing power distribution system in place and building a new power distribution system service to serve both east and main docks. Once the new power system service is installed, new feeders and slip power pedestals and related distribution equipment can be installed, one at a time, to each slip. When the new power distribution system is in place, the existing old distribution power pedestals and related feeders/conduits can be removed back to source service panel. This phased construction approach minimizes the down time for each slip and allows the existing power distribution systems to be upgraded without shutting down the entire east and main docks for the duration of the construction.

The second cost option includes installing new feeders and power pedestals and related distribution equipment to serve slips in the main docks, one at a time, to each slip. When the new power distribution system is in place, the existing old distribution power pedestals and related feeders/conduits can be removed back to source service panel.

The third cost option is to review the existing power distribution system serving the east marina docks and determine a relative cost to upgrade the distribution system to correct system voltage drop, power demand and Code deficiencies. This option would include leaving the existing power distribution system in place and building a new power distribution system service to serve east docks and future dock expansions.

Once the new power system service is installed, new feeders and slip power pedestals and related distribution equipment can be installed, one at a time, to each slip. When the new power distribution system is in place, the existing old distribution power pedestals and related feeders/conduits can be removed back to source service panel. New feeder conduits stubb-outs to serve future east dock expansion project(s) will be installed and spare space in the main distribution panel and meter centers will be provided to accommodate anticipated future slip loads.

In summary, the conceptual opens are as follows:

- d) Upgrade the west dock power distribution system (phase 1)
- e) Upgrade the main dock power distribution system (phase 2)
- f) Upgrade the east dock power distribution system (phase 3)

#### **OPINION OF PROBABLE COSTS**

We have included an Opinion of Probable costs for the owners use in determining the order of magnitude required to upgrade the existing power distribution systems serving the docks. There are many different factors that can affect the overall cost of the distribution system upgrades. Our values are determined as a median value and we would expect a range of costs for this work depending on many different scope factors. Therefore, we recommend a 10% range both above and below the costs identified.

#### **SEE ATTACHED ESTIMATE OF PROBABLE CONSTRUCTION COSTS IN APPENDIX.**

### **E. CONCLUSIONS**

#### **1. Condition of Use**

The Marina Maintenance Staff have been experiencing voltage drop problems in the existing electrical distribution systems serving the boat docks at the Marina due to following:

1. Inadequate 208 V service connection (should be 240V, three phase, 4 wire).
2. Overloaded feeder circuits (too many power pedestals on a circuit).
3. Undersize feeder and branch circuits for long runs (Feeder and branch circuit conductors should be increased in size of long circuit runs, so that overall voltage drop from source panel to load does not exceed 5% of 240 Volts (max 12 V voltage drop)).

The existing marina power distribution systems should be replaced with a new power distribution systems to address the Code deficiencies noted in the report, fix the low voltage problem, correct the feeder and branch circuit overloading conditions, raise the main power distribution equipment above the FEMA flood plain, raise the electrical connections above the normal highest tide electrical datum line, mitigate grounding system leakage currents in water (may cause accelerated corroding of boats with metallic hulls), provide reliable ground fault protected circuits and create a safe environment for the Marina Staff and Customers.

## **2. Opinion of Probable Costs**

The Costs provided are suggested as a range of costs required to upgrade the marina electrical distribution system serving the existing east and west docks and put the docks electrical distribution system back into usable service for general marine vessel and tenant use.

## **APPENDICES**

- Appendix A    Photos**
- Appendix B    Bibliography of Reviewed Documents**
- Appendix C    Codes and Standards**
- Appendix D    Cost Estimate**
- Appendix E    Field Survey Drawings**
- Appendix F    Electrical Risers & Voltage Drop Calculations**

# **APPENDIX A –**

## **PHOTOS**




PHOTO 1- Shore Power Voltage Step-up Transformer



PHOTO 2- Service Panel "MSP1" with bottom of cabinet rusted-out.




PHOTO 3- Service Switch "MSP2" with rusted-out bottom of enclosure



PHOTO 4- Feeder Conduits Not Supported




PHOTO 5- Feeder Tap Box "FT2"




PHOTO 6- Feeder Tap Box "FT1" without feeder ground fault protection




PHOTO 7- Electrical Datum Line Markings on Piling (one for west main docks and the other for east docks)




PHOTO 8- Cables not Supported



PHOTO 9- Fuel EPO Shut-Off PB Less than 20' from fuel dispenser




PHOTO 10- Improper Support of Power Cord



**PHOTO 11-** Service Panel MSP3 Rusted-Out Bottom




PHOTO 12- Service Panel "MSP3" and service switch "MSP4"




PHOTO 13- Panel With Significant Rust




PHOTO 14- Fuel Dock House Sub-Panel- Panel and Branch Circuits Not Labeled Properly





PHOTO 15- Feeder Circuit Handhole in Front of Main Dock



**PHOTO 16-** Power Cord "Y" Adapter Required For Larger Vessels With Larger Than 50A/2P Service And To Reduce Voltage Drop




PHOTO 17- Power Pedestal with Excessive Corrosion




PHOTO 18- Voltage Booster Transformer



PHOTO 19- Power Pedestal with Significant Deterioration




PHOTO 20- Feeder Tap Box "FT2" Without Feeder Circuit Ground Fault Protection



**PHOTO 21-** Starship II Rental Office Handrail Routed Over Panelboard Cover



PHOTO 22- Shore Power Pedestal




PHOTO 23- Service Panel "MSP3" and Meter Center "MC"

## **APPENDIX B –**

# **BIBLIOGRAPHY OF REVIEWED DOCUMENTS**

**Project #:**      **87-37**

**Project Name:**    **CLEARWATER MARINA  
NEW FUEL DISPENSING SYSTEM**


**Job #:**            **8825 E-D**


**Consultant:**      **N/A**


**Engineering: Document Name Use Job #.**

17041

### LEGEND







# CITY OF CLEARWATER

## Clearwater Marina Phase II Expansion 1973

### CITY OFFICIALS

H. Everett Hougen  
Donald S. Williams  
Richard "Dick" Wachtler  
Dr. Joseph L. Carwise  
Rick Hall  
Merrett R. Stierheim

Mayor  
Commissioner  
Commissioner  
Commissioner  
Commissioner  
City Manager

### Drawing Index

- 1 PIER PLAN & MISC. DETAIL
- 2 DEMOLITION PLAN
- 3 CONCRETE PILE LOCATION & SEAWALL DETAILS
- 4 PIER DETAILS
- 5 WATER, POWER & LIGHTING
- 6 SANITARY WASTE COLLECTION




Job No.

Approved by Max G. Battle  
Max G. Battle  
City Engineer

one Doc.  
13  
E.S.



73101



WASH PROBES  
Clearwater Marina Phase II Expansion  
1973  
DATE 3-16-73 SCALE 1"=50' DRAWN BY FJB REVISED

SHEET 2 OF 2

73101



WASH PROBES  
Clearwater Marina Phase II Expansion  
1973  
DATE 3-16-73 SCALE 1"=50' DRAWN BY FJB REVISED

SHEET 1 OF 2

WASH PROBES  
Clearwater Marina Phase II Expansion  
1973  
DATE 3-16-73 SCALE 1"=50' DRAWN BY FJB REVISED

SHEET 2 OF 2


73101

# Clearwater Marina Phase II Expansion 1973

Detail

16 PIER PLAN & MISC. DETAIL

3-73




16 Pier Plan & MISC. DETAIL

73101

Clearwater Marina Phase II Expansion - 1973

WATER POWER & LIGHTING

Detail



# **APPENDIX C –**

# **CODES AND STANDARDS**

# ARTICLE 555

# MARINAS AND BOATYARDS

## Introduction to Article 555—Marinas and Boatyards

Water levels aren't constant. Ocean tides rise and fall, while lakes and rivers vary in depth in response to rain. To provide power to a marina or boatyard, you must allow for these variations in water level between the point of use and the power source. Article 555 addresses this issue.

This article begins with the concept of the electrical datum plane. You might think of it as the border of a "demilitarized zone" for electrical equipment. Or, you can think of it as a line that marks the beginning of a "no man's land" where you simply don't place electrical equipment. Once you determine where this plane is, don't locate transformers, connections, or receptacles below that line.

### 555.1 Scope

Article 555 covers the installation of wiring and equipment for fixed or floating piers, wharfs, docks, and other areas in marinas, boatyards, boat basins, boathouses, and similar occupancies. This article doesn't apply to docking facilities or boathouses used for the owners of single-family dwellings. [Figure 555–1](#)

#### Author's Comment:

- GFCI protection is required for outdoor 15A and 20A, 125V receptacles [210.8].

### 555.2 Definitions

#### Electrical Datum Plane.

**(1) Land Area Subject to Tidal Fluctuation.** The horizontal plane 2 ft above the highest high tide that occurs under normal circumstances. [Figure 555–2](#)




Figure 555–1

**(2) Land Areas Not Subject to Tidal Fluctuation.** The horizontal plane 2 ft above the highest water level that occurs under normal circumstances. [Figure 555–3](#)




Figure 555-2




Figure 555-4




Figure 555-3

**(3) Floating Piers.** The horizontal plane 30 in. above the water level at the floating pier and a minimum of 12 in. above the level of the deck. Figure 555-4

**Author's Comment:**

- This definition is necessary for the location of transformers [555.5], electrical connections [555.9], and receptacles [555.19] near water.

**Marine Power Outlet.** An enclosed assembly that can include equipment such as receptacles, circuit breakers, fused switches, fuses, watt-hour meters, panelboards, and monitoring means approved for marine use. Figure 555-5




Figure 555-5

**Author's Comment:**

- This definition is necessary for the application of shore power receptacles [555.19(A)(1)] and disconnecting means [555.17(B)].

### 555.3 Ground-Fault Protection

The overcurrent device for the main marina feeder conductors must have ground-fault protection not exceeding 100 mA. If ground-fault protection is provided for each individual marina branch or feeder circuit, ground-fault protection isn't required for the main marina feeder conductors. **Figure 555–6**

#### Ground-Fault Protection of Main Feeder 555.3



The overcurrent protective device for the main marina feeder conductors must have ground-fault protection not exceeding 100 mA. If ground-fault protection is provided for each individual marina branch or feeder circuit, ground-fault protection isn't required for the main marina feeder conductors.

Copyright 2014, www.MikeHolt.com

Figure 555–6

### 555.5 Transformers

Transformers must be approved by the authority having jurisdiction for the location, and the bottom must not be located below the electrical datum plane. **Figure 555–7**

### 555.7 Location of Service Equipment

Service equipment for floating docks or marinas isn't permitted to be located on the floating structure.




Figure 555–7

### 555.9 Electrical Connections

**Floating Piers.** Electrical connections must be located not less than 12 in. above the deck of a floating pier, unless the conductor splices are contained within approved junction boxes utilizing sealed wire connector systems listed and identified for submersion located above the waterline but below the electrical datum plane for floating piers. **Figure 555–8** and **Figure 555–9**




Figure 555–8




Figure 555-9

**Fixed Piers.** For a fixed pier, electrical connections must be located not less than 12 in. above the deck, and never below the electrical datum plane. **Figure 555-10**




Figure 555-10

## 555.10 Electrical Equipment Enclosures

**(A) Securing and Supporting.** Electrical equipment enclosures must be securely and substantially supported by structural members, independent of any raceway connected to them.

**(B) Location.** Electrical equipment enclosures on piers must be located so as not to interfere with mooring lines.

## 555.12 Load Calculations for Service and Feeder Conductors

The calculated ungrounded and neutral service or feeder load for shore power receptacles can be calculated using the adjustment factors contained in Table 555.12.

**Table 555.12 Adjustment Factors**

Number of Receptacles	Sum of the Rating of the Receptacles
1–4	100%
5–8	90%
9–14	80%
15–30	70%
31–40	60%
41–50	50%
51–70	40%
Over 71	30%

**Table Note 1.** If shore power provides two receptacles having different voltages for an individual boat slip, only the receptacle with the larger kilowatt demand rating is required to be included in the calculation. **Figure 555-11**

Marinas and Boatyards – Shore Power Calculations  
Table 555.12, Note 1




Figure 555-11

**Question:** What size 120/240V, single-phase service is required for a marina with twenty 20A, 125V receptacles, and twenty 30A, 250V receptacles? **Figure 555–12**

- (a) 200A      (b) 400A      (c) 600A      (d) 800A

**Answer:** (c) 600A

**Step 1:** Determine the receptacle load per line.

Line 1	Line 2
Twenty 20A, 125V	200A
Twenty 30A, 250V	200A (ten each line)
<u>+ 600A</u>	<u>+ 600A</u> (twenty each line)
800A	800A

**Step 2:** The calculated load per line for the marina is based on the demand factors listed in Table 555.12 for 30 receptacles (per line).  $800A \times 0.70 = 560A$




Figure 555–12

#### Author's Comment:

- There are 40 receptacles in this example but because the 125A are balanced between Line 1 and Line 2 the maximum receptacles connected to any one line after balancing is 30.

## 555.13 Wiring Methods and Installation

### (A) Wiring Methods.

**(1) General.** Any Chapter 3 wiring method is permitted if identified for use in wet locations.

**(2) Portable Power Cables.** Sunlight resistant, extra-hard usage portable power cables listed for wet locations having an outer jacket resistant to temperature extremes, oil, gasoline, ozone, abrasion, acids, and chemicals.

### (B) Installation.

#### (4) Portable Power Cables.

(a) Portable power cables permitted by 555.13(A)(2) must be:

- (1) Properly supported.
- (2) Located on the underside of the pier.
- (3) Securely fastened by nonmetallic clips to structural members other than the deck planking.
- (4) Not be subject to physical damage.

(5) Protected against chafing by a permanently installed oversized sleeve of nonmetallic material when cables pass through structural members.

**(5) Protection.** Raceways must be used to protect wiring above decks of piers and landing stages.

## 555.15 Grounding

**(B) Equipment Grounding Conductor.** The equipment grounding conductor must be an insulated conductor with a continuous outer finish that's green or green with one or more yellow stripes. **Figure 555–13**

**(C) Size of Equipment Grounding Conductor.** The insulated equipment grounding conductor must be sized in accordance with 250.122, based on the rating of the overcurrent device, but not smaller than 12 AWG.




Figure 555-13

## 555.17 Boat Receptacle Disconnecting Means

A disconnecting means must isolate each boat from its shore power receptacle.

**(A) Type of Disconnect.** A circuit breaker or switch (or both) must be used to serve as the required shore power receptacle disconnecting means and it must be identified as to which receptacle it controls. Figure 555-14




Figure 555-14

**(B) Location.** The disconnecting means for shore power receptacles must be readily accessible and located not more than 30 in. from the receptacle it controls. Circuit breakers or switches located in marine power outlets can be used for the boat receptacle disconnecting means. Figure 555-15




Figure 555-15

### Author's Comment:

- This shore power receptacle disconnecting means is intended to eliminate the hazard of someone engaging or disengaging the boat's shore power attachment plug with wet, slippery hands, and possibly contacting energized blades. The "30-in. requirement" helps someone not familiar with the marina layout to quickly reach the disconnecting means in an emergency.

## 555.19 Receptacles

Receptacles must be mounted not less than 12 in. above the deck surface of the pier, and not below the electrical datum plane on a fixed pier. Figure 555-16

### (A) Shore Power Receptacles.




Figure 555-16




Figure 555-17

**(1) Enclosures.** Receptacles intended to supply shore power to boats must be part of a listed marina power outlet enclosure, be installed in listed enclosures protected from the weather, or in listed weather-proof enclosures. The integrity of the assembly must not be affected when the receptacles are in use with a booted or nonbooted attachment plug/cap inserted.

**(3) Branch Circuits.** An individual branch circuit of the voltage class and rating corresponding to the rating of the receptacle must supply each receptacle that supplies shore power to boats.



Note: Supplying 120/240V 3-wire receptacles from a 120/208V 3-wire supply may cause overheating or malfunctioning of connected equipment.

**(4) Ratings.** Single receptacles that provide shore power for boats must be rated not less than 30A.

- (a) Receptacles rated 30A and 50A must be of the locking and grounding type. **Figure 555-17**
- (b) Receptacles rated 60A or 100A must be of the pin and sleeve type.

#### Author's Comment:

- The rating of the shore power receptacle doesn't depend upon the length of the boat. The *Code* simply sets a minimum rating of 30A and leaves it up to the designer and/or owner to provide the receptacles they deem necessary based on the projected usage of the slips.

#### (B) Other Than Shore Power.

**(1) GFCI Protection of Receptacles.** 15A and 20A, 125V receptacles installed outdoors, in boathouses, buildings/structures used for storage, maintenance, or repair for portable electric hand tools, electrical diagnostic equipment, or portable lighting equipment must be GFCI protected. **Figure 555-18**





Figure 555-18

## 555.22 Repair Facilities

Electrical wiring and equipment at marine craft repair facilities containing flammable or combustible liquids or gases must comply with Article 511 in addition to the requirements of Article 555. **Figure 555-19**

### Author's Comment:

- Important rules in Article 511 to consider include:
  - 511.3 Classification of Hazardous Areas
  - 511.4 Wiring and Equipment in Hazardous (Classified) Locations
  - 511.7 Wiring and Equipment Above Hazardous (Classified) Locations
  - 511.9 Explosionproof Seals
  - 511.12 GFCI-Protected Receptacles

### Repair Facilities for Marine Craft 555.22





Figure 555-19

NFPA 70®

# 2014 HANDBOOK

Mark W. Earley  
Christopher D. Coache  
Mark Cloutier  
Gil Moniz



National Electrical Code®  
International Electrical Code® Series

This section is new in the 2014 Code. Feeders and services rated at 480/277 V where the disconnect is rated 1000 A or more are required to have ground-fault protection of equipment. A branch circuit supplying an industrial machine may be supplied by a feeder with a similar rating. This new section extends the ground-fault protection requirement to branch circuits. Exceptions are provided for continuous industrial processes where shutdown could introduce additional or increased hazards, and for installations where ground-fault protection is provided upstream of the branch circuit on the load side of a transformer supplying the branch circuit. For further information on ground-fault protection of equipment, see commentary following 230.95.

**Informational Note:** For buildings that contain health care occupancies, see the requirements of 517.17.

**Exception No. 1:** *The provisions of this section shall not apply to a disconnecting means for a continuous industrial process where a nonorderly shutdown will introduce additional or increased hazards.*

**Exception No. 2:** *The provisions of this section shall not apply if ground-fault protection of equipment is provided on the supply side of the branch circuit and on the load side of any transformer supplying the branch circuit.*

### 210.17 Electric Vehicle Branch Circuit

An outlet(s) installed for the purpose of charging electric vehicles shall be supplied by a separate branch circuit. This circuit shall have no other outlets.


This section is new for the 2014 Code. Electric vehicle supply equipment is a continuous load that usually operates for several hours. Most electric vehicle supply equipment for consumers is rated at 12 A at 120 V or 32 A at 240 V. On a shared branch circuit, the overcurrent protective device could trip due to overload. For these loads, the branch-circuit rating should be 125 percent of the load. In this example, the 120-V branch circuit would be supplied by a 15-A circuit, while the 240-V circuit would be supplied by a 40-A circuit.

**Informational Note:** See 625.2 for the definition of *Electric Vehicle*.

### 210.18 Guest Rooms and Guest Suites

Guest rooms and guest suites that are provided with permanent provisions for cooking shall have branch circuits installed to meet the rules for dwelling units.

Guest rooms and guest suites equipped with permanent provisions for cooking must meet all of the branch-circuit requirements for dwelling units contained in Article 210. The guest suite configuration shown in Exhibit 210.23 triggers the requirement to install the branch-circuit wiring in this unit using all of the branch-circuit provisions that apply to dwelling units.



**EXHIBIT 210.23** Guest rooms or suites with permanent provisions for cooking in which the installation of branch circuit must follow all of the requirements in Article 210 covering dwelling units.

## II. Branch-Circuit Ratings

### 210.19 Conductors — Minimum Ampacity and Size

#### (A) Branch Circuits Not More Than 600 Volts.

**Informational Note No. 1:** See 310.15 for ampacity ratings of conductors.

**Informational Note No. 2:** See Part II of Article 430 for minimum rating of motor branch-circuit conductors.

**Informational Note No. 3:** See 310.15(A)(3) for temperature limitation of conductors.

**Informational Note No. 4:** Conductors for branch circuits as defined in Article 100, sized to prevent a voltage drop exceeding 3 percent at the farthest outlet of power, heating, and lighting loads, or combinations of such loads, and where the maximum total voltage drop on both feeders and branch circuits to the farthest outlet does not exceed 5 percent, provide reasonable efficiency of operation. See Informational Note No. 2 of 215.2(A)(1)(b) for voltage drop on feeder conductors.


Excessive voltage drop in supply conductors can cause trouble in and lead to inefficient operation of electrical equipment. Under-voltage conditions reduce the capability and reliability of motors, lighting sources, heaters, and solid-state equipment. It may be necessary to compensate for this with an installation beyond the minimum requirements. Sample voltage-drop calculations are found in the commentary following 215.2(A)(1), Informational Note No. 3, and following Table 9 in Chapter 9.

**(1) General.** Branch-circuit conductors shall have an ampacity not less than the maximum load to be served. Conductors shall be sized to carry not less than the larger of 210.19(A)(1)(a) or (b).

**(a)** Where a branch circuit supplies continuous loads or any combination of continuous and noncontinuous loads, the minimum branch-circuit conductor size shall have an allowable ampacity not less than the noncontinuous load plus 125 percent of the continuous load.

and equipped with a manual override that allows the sensor to function as a wall switch.

**(C) Other Than Dwelling Units.** For attics and underfloor spaces containing equipment requiring servicing, such as heating, air-conditioning, and refrigeration equipment, at least one lighting outlet containing a switch or controlled by a wall switch shall be installed in such spaces. At least one point of control shall be at the usual point of entry to these spaces. The lighting outlet shall be provided at or near the equipment requiring servicing.



## ARTICLE 215

### Feeders

#### 215.1 Scope

This article covers the installation requirements, overcurrent protection requirements, minimum size, and ampacity of conductors for feeders supplying branch-circuit loads.

*Exceptions: Feeders for electrolytic cells as covered in 668.3(C)(1) and (C)(4).*

#### 215.2 Minimum Rating and Size

##### (A) Feeders Not More Than 600 Volts.

**(1) General.** Feeder conductors shall have an ampacity not less than required to supply the load as calculated in Parts III, IV, and V of Article 220. Conductors shall be sized to carry not less than the larger of 215.2(A)(1)(a) or (b).

This section was revised for the 2014 Code. The ampacity of the feeder conductors is required to be based on the larger of the continuous load (at 125 percent) plus the continuous load (at 100 percent) or the maximum load to be served after any adjustments or correction factors.

(a) Where a feeder supplies continuous loads or any combination of continuous and noncontinuous loads, the minimum feeder conductor size shall have an allowable ampacity not less than the noncontinuous load plus 125 percent of the continuous load.

(b) The minimum feeder conductor size shall have an allowable ampacity not less than the maximum load to be served after the application of any adjustment or correction factors.

Informational Note No. 1: See Examples D1 through D11 in Informative Annex D.

Informational Note No. 2: Conductors for feeders, as defined in Article 100, sized to prevent a voltage drop exceeding 3 percent at the farthest outlet of power, heating, and lighting loads, or combinations of such loads, and where the maximum total voltage drop

on both feeders and branch circuits to the farthest outlet does not exceed 5 percent, will provide reasonable efficiency of operation. Informational Note No. 3: See 210.19(A), Informational Note No. 4, for voltage drop for branch circuits.

Reasonable operating efficiency is achieved if the voltage drop of a feeder or a branch circuit is limited to 3 percent. However, the total voltage drop of a branch circuit plus a feeder can reach 5 percent and still achieve reasonable operating efficiency. See Article 100 for the definitions of *feeder* and *branch circuit*.

The 5 percent voltage-drop value is explanatory material and, as such, appears as an informational note. The informational notes covering voltage drop are not mandatory (see 90.5). Where circuit conductors are increased due to voltage drop, 250.122(B) requires an increase in circular mil area for the associated equipment grounding conductors.

The resistance or impedance of conductors may cause a substantial difference between voltage at service equipment and voltage at the point-of-utilization equipment. Excessive voltage drop impairs the starting and the operation of electrical equipment. Undervoltage can result in inefficient operation of heating, lighting, and motor loads. An applied voltage of 10 percent below rating can result in a decrease in efficiency of substantially more than 10 percent – for example, fluorescent light output would be reduced by 15 percent, and incandescent light output would be reduced by 30 percent. Induction motors would run hotter and produce less torque. With an applied voltage of 10 percent below rating, the running current would increase 11 percent, and the operating temperature would increase 12 percent. At the same time, torque would be reduced 19 percent.

In addition to resistance or impedance, the type of raceway or cable enclosure, the type of circuit (ac, dc, single-phase, 3-phase), and the power factor should be considered to determine voltage drop.

This basic formula can be used to determine the voltage drop in a 2-wire dc circuit, a 2-wire ac circuit, or a 3-wire ac single-phase circuit, all with a balanced load at 100 percent power factor and where reactance can be neglected:

$$VD = \frac{2 \times L \times R \times I}{1000}$$

where:

*VD* = voltage drop (based on conductor temperature of 75°C)

*L* = one-way length of circuit (ft)

*R* = conductor resistance in ohms ( $\Omega$ ) per 1000 ft (from Chapter 9, Table 8)

*I* = load current (amperes)

For 3-phase circuits (at 100 percent power factor), the voltage drop between any two phase conductors is 0.866 times the voltage drop calculated by the preceding formula. See the commentary following Chapter 9, Table 9, for an example of voltage-drop calculation using ac reactance and resistance. Voltage-drop tables and calculations are also available from various manufacturers.

# STANDARD

**ANSI/ASHRAE/IES Standard 90.1-2013**  
(Supersedes ANSI/ASHRAE/IES Standard 90.1-2010)  
Includes ANSI/ASHRAE/IES Addenda listed in Appendix F

# Energy Standard for Buildings Except Low-Rise Residential Buildings (I-P Edition)


See Appendix F for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, the IES Board of Directors, and the American National Standards Institute.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site ([www.ashrae.org](http://www.ashrae.org)) or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE Web site ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2013 ASHRAE

ISSN 1041-2336





## 8. POWER

### 8.1 General

**8.1.1 Scope.** This section applies to all building power distribution systems and only to equipment described below.

**8.1.2 New Buildings.** Equipment installed in new buildings shall comply with the requirements of this section.

**8.1.3 Addition to Existing Buildings.** Equipment installed in addition to existing buildings shall comply with the requirements of this section.

#### 8.1.4 Alterations to Existing Buildings

**Exception:** Compliance shall not be required for the relocation or reuse of existing equipment at the same site.

**8.1.4.1 Alterations to building service equipment or systems** shall comply with the requirements of this section applicable to those specific portions of the building and its systems that are being altered.

**8.1.4.2 Any new equipment subject to the requirements of this section that is installed in conjunction with the alterations as a direct replacement of existing equipment shall comply with the specific requirements applicable to that equipment.**

### 8.2 Compliance Paths

**8.2.1 Compliance.** Power distribution systems in all projects shall comply with the requirements of Section 8.1, "General"; Section 8.4, "Mandatory Provisions"; and Section 8.7, "Submittals."

### 8.3 Simplified/Small Building Option (Not Used)

### 8.4 Mandatory Provisions

#### 8.4.1 Voltage Drop

**Exception:** Feeder conductors and branch circuits that are dedicated to emergency services

**8.4.1.1 Feeders.** Feeder conductors shall be sized for a maximum voltage drop of 2% at design load.

**8.4.1.2 Branch Circuits.** Branch circuit conductors shall be sized for a maximum voltage drop of 3% at design load.

**8.4.2 Automatic Receptacle Control.** The following shall be automatically controlled:

- a. At least 50% of all 125-volt 15- and 20-amp receptacles in all private offices, conference rooms, rooms used primarily for printing and/or copying functions, break rooms, classrooms, and individual workstations
- b. At least 25% of branch circuit feeders installed for modular furniture not shown on the construction documents

This control shall function on

- a. a scheduled basis using a time-of-day operated control device that turns receptacles off at specific programmed times—an independent program schedule shall be provided for controlled areas of no more than 5000 ft<sup>2</sup> and not more than one floor (the occupant shall be able to manually override the control device for up to two hours),
- b. an occupant sensor that shall turn receptacles off within 20 minutes of all occupants leaving a space, or
- c. an automated signal from another control or alarm system that shall turn receptacles off within 20 minutes after determining that the area is unoccupied.

All controlled receptacles shall be permanently marked to visually differentiate them from uncontrolled receptacles and are to be uniformly distributed throughout the space.

Plug-in devices shall not be used to comply with Section 8.4.2.

**Exceptions:** Receptacles for the following shall not require an automatic control device:

1. Receptacles specifically designated for equipment requiring continuous operation (24 hours/day, 365 days/year)
2. Spaces where an automatic control would endanger the safety or security of the room or building occupant(s).

#### 8.4.3 Electrical Energy Monitoring


**8.4.3.1 Monitoring.** Measurement devices shall be installed in new buildings to monitor the electrical energy use for each of the following separately:

- a. Total electrical energy
- b. HVAC systems
- c. Interior lighting
- d. Exterior lighting
- e. Receptacle circuits

For buildings with tenants, these systems shall be separately monitored for the total building and (excluding shared systems) for each individual tenant.

**Exception:** Up to 10% of the load for each of the categories (b) through (e) shall be allowed to be from other electrical loads.

**8.4.3.2 Recording and Reporting.** The electrical energy usage for all loads specified in Section 8.4.3.1 shall be recorded a minimum of every 15 minutes and reported at least hourly, daily, monthly, and annually. The data for each tenant space shall be made available to that tenant. The system shall



# Coastal Construction Manual

Principles and Practices of Planning, Siting, Designing,  
Constructing, and Maintaining Residential Buildings  
in Coastal Areas (Fourth Edition)

FEMA P-55 / Volume I / August 2011



FEMA

designations; and BFE contours throughout the SFHA. FIRMs in coastal areas may also show the LiMWA. Communities can use the information provided in FIS reports and FIRMs to manage SFHA development. At the same time, FEMA uses the FIS and FIRMs to establish insurance premiums for houses and other buildings. The information pertaining to the BFE and the flood zone at the building site are of particular importance for a coastal construction project.

### 5.2.3 Minimum Regulatory Requirements

The floodplain management ordinances or laws adopted by communities that participate in the NFIP must meet or exceed the minimum NFIP regulatory requirements set forth at Title 44 of the Code of Federal Regulations (CFR) Section 60.3 (44 CFR § 60.3). Community floodplain management regulations include requirements in the SFHA that apply to new construction, substantially improved buildings, and substantially damaged buildings in both Zone A and Zone V. Additional requirements apply to new subdivisions and other development in the SFHA.

The minimum NFIP requirements for new construction, substantially improved, and substantially damaged buildings affect the type of foundation that can be used, establishes the required height of the lowest floor to or above the BFE, establishes the criteria for the installation of building utility systems, requires the use of flood damage-resistant materials, and limits the use of the area below the lowest floor. In recognition of the greater hazard posed by breaking waves 3 feet high or higher, FEMA has established minimum NFIP regulatory requirements for Zone V buildings that are more stringent than the minimum requirements for Zone A buildings. Therefore, the location of a building in relation to the Zone A/Zone V boundary on a FIRM can affect the design of the building. In that regard, it is important to note that if a building or other structure has any portion of its foundation in Zone V, it must be built to comply with Zone V requirements.

The following sections summarize the minimum NFIP requirements (for the exact wording of the regulations, refer to 44 CFR § 60.3): Section 5.2.3.1 describes the minimum requirements that apply throughout the SFHA. Sections 5.2.3.2 and 5.2.3.3 describe requirements specific to Zone A and Zone V, respectively.

#### 5.2.3.1 Minimum Requirements in All SFHAs

The minimum NFIP floodplain management requirements for all SFHAs affect buildings, subdivisions and other new development, new and replacement water supply systems, and new and replacement sanitary sewage systems. These requirements, set forth at 44 CFR § 60.3(a) and (b), are summarized in Table 5-1.




#### WARNING

Communities participating in the NFIP are encouraged to adopt and enforce floodplain management ordinances or laws more stringent than the minimum requirements of the NFIP regulations. For example, some States and communities require that buildings be elevated above rather than simply to the BFE. The additional elevation is referred to as freeboard (see Figure 5-4). Check with local floodplain managers and building officials concerning such requirements.



#### WARNING

The guidance in this Manual was not specifically developed for manufactured housing. For NFIP requirements concerning manufactured housing, refer to 44 CFR Section 60.3 and FEMA P-85, *Protecting Manufactured Homes from Flood and Other Hazards, A Multi-Hazard Foundation and Installation Guide* (FEMA 2009a).




**Figure 5-2.**  
Recommended elevation for buildings in Coastal A Zone and Zone V compared to minimum requirements

Table 5-2. Summary of NFIP Regulatory Requirements and Recommendations for Exceeding the Requirements (continued)

	Zone V 	Coastal A Zone 	Zone A 
<b>Walls of Enclosures<sup>(g)</sup> (continued)</b>	<p><b>Recommendations and Requirements<sup>(a)</sup></b></p> <p><b>Requirement:</b> Walls must be designed to collapse (break away) under flood loads to allow free passage of floodwaters without damaging the structure or supporting foundation system. Utilities and equipment must not be mounted on or pass through breakaway walls.</p> <p><b>Cross Reference<sup>(b)</sup></b></p> <p>FEMA P-499: 8.1 Other: FEMA TB-9</p>	<p><b>Recommendations and Requirements<sup>(a)</sup></b></p> <p><b>Requirement:</b> Follow the Zone V recommendation and requirements.</p> <p><b>Cross Reference</b></p>	<p><b>Recommendations and Requirements<sup>(a)</sup></b></p> <p><b>Requirement:</b> FEMA P-499: 3.1, 3.5, 8.1 Other: FEMA TB-1 and TB-9</p> <p><b>Cross Reference</b></p>
<b>UTILITIES</b>	<p><b>Electrical, Heating, Ventilation, Plumbing and Air Conditioning Equipment</b></p> <p><b>Recommendation:</b> Locate equipment on the landward side of building, and/or behind structural element.</p> <p><b>Requirement:</b> Utilities and equipment must be located (elevated) and designed to prevent flood waters from entering and accumulating in components during flooding.</p> <p><b>NFIP:</b> 60.3(a)(3)(iv) <b>IRC:</b> R322.1.6, RM1301.1.1, RM1401.5, RM1601.4.9, RM1701.2, RM2001.4, RM2201.6, RG2404.7, RP2601.3, RP2602.2, RP2705.1, RP2101.5 <b>IBC:</b> 1403.5, 1403.6, 1612.4 <b>ASCE 24:</b> Ch. 7 <b>FEMA P-55:</b> Ch. 12 <b>FEMA P-499:</b> 8.3 Other: FEMA P-348, FEMA TB-5</p>	<p><b>Recommendation:</b> Follow the Zone V recommendation and requirements.</p> <p><b>Requirement:</b> Utilities and equipment must be located (elevated) and designed to prevent flood waters from entering and accumulating in components during flooding.</p> <p><b>NFIP:</b> 60.3(a)(3)(iv) <b>IRC:</b> R322.1.6, RM1301.1.1, RM1401.5, RM1601.4.9, RM1701.2, RM2001.4, RM2201.6, RG2404.7, RP2601.3, RP2602.2, RP2705.1, RP2101.5 <b>IBC:</b> 1403.5, 1612.4 <b>ASCE 24:</b> Ch. 7 <b>FEMA P-55:</b> Ch. 12 <b>FEMA P-499:</b> 8.3 Other: FEMA P-348, FEMA TB-5</p>	<p><b>Recommendation:</b> Locate equipment on the landward or downstream side of building, and/or behind structural element.</p> <p><b>Requirement:</b> Utilities and equipment must be located (elevated) and designed to prevent flood waters from entering and accumulating in components during flooding.</p> <p><b>NFIP:</b> 60.3(a)(3)(iv) <b>IRC:</b> R322.1.6, RM1301.1.1, RM1401.5, RM1601.4.9, RM1701.2, RM2001.4, RM2201.6, RG2404.7, RP2601.3, RP2602.2, RP2705.1, RP2101.5 <b>IBC:</b> 1403.5, 1612.4 <b>ASCE 24:</b> Ch. 7 <b>FEMA P-55:</b> Ch. 12 <b>FEMA P-499:</b> 8.3 Other: FEMA P-348</p>

# **APPENDIX D –**

## **COST ESTIMATE**



LONG & ASSOCIATES

ARCHITECTS / ENGINEERS, INC.

4525 South Manhattan Avenue, Tampa, Florida, 33611-2305 T: (813) 839-0506 F: (813) 839-4616 AAC001624 1828 CGC1511025

[www.longandassociates.com](http://www.longandassociates.com)

## CLEARWATER BEACH MARINA ELECTRICAL DISTRIBUTION EVALUATION & FEASIBILITY STUDY

A/E # 17039


### 25 CAUSEWAY BLVD, CLEARWATER BEACH, FL

OPINION OF PROBABLE COST - MAIN/WEST DOCK SERVICE AND MAIN DOCK DSB

OPTION 1

9/14/2018

COMPONENT DESCRIPTION	AREA	UNITS	UNIT COST	SUBTOTAL	TOTAL
<b>GENERAL REQUIREMENTS</b>					
TEMPORARY UTILITIES & FACILITIES	6 MO	\$ 2,500.00	\$ 15,000		\$ 97,338
UNDERGROUND UTILITY LOCATION	1 DAY	\$ 900.00	\$ 900		
CLEANING & WASTE MANAGEMENT	13250 SF	\$ 0.75	\$ 9,938		
SUPERVISION (FULL TIME)	6 MO	\$ 7,500.00	\$ 45,000		
PEDESTRIAN PROTECTION	13250 SF	\$ 2.00	\$ 26,500		
SELECTIVE DEMOLITION (INTERIOR)	0 SF	\$ 2.50	\$ -		
<b>SITEWORK/CIVIL</b>					
CONCRETE DEMO	1600 SF	\$ 0.75	\$ 1,200		\$ 18,965
ASPHALT DEMO	0 SF	\$ 0.50	\$ -		
CLEAR & GRUB	0 SF	\$ 0.25	\$ -		
EXCAVATION	240 CY	\$ 6.00	\$ 1,440		
Directional Bore (HDPE conduits)	100 LF	\$ 26.00	\$ 2,600		
NEW CONCRETE PATCH	1600 SF	\$ 7.00	\$ 11,200		
GRAVEL	15 CY	\$ 80.00	\$ 1,200		
SOD	265 SY	\$ 5.00	\$ 1,325		
<b>STRUCTURAL</b>					
Steel	12 Tons	\$ 4,500.00	\$ 54,000		\$ 97,725
Pile Caps	7 CYD	\$ 800.00	\$ 5,600		
1 1/2" Bar Grading	375 SF	\$ 35.00	\$ 13,125		
Stair w/ Grading Tread	1 EA	\$ 9,000.00	\$ 9,000		
2-Line Hand Rail	85 FT	\$ 40.00	\$ 3,400		
Concrete Piles 6 * 30 FT	180 FT	\$ 70.00	\$ 12,600		
<b>ELECTRICAL</b>					
Remove Duke Energy Power Vault and re-work primary circuits	1 LS	\$ 100,000.00	\$ 100,000		\$ 876,712
New Duke Transformer/Primary Circuit	1 LS	\$ 75,000.00	\$ 75,000		
New Switchboards and Transformer	1 LS	\$ 193,583.00	\$ 193,583		
New Feeders	1 LS	\$ 332,129.00	\$ 332,129		
New Power Pedestals	1 LS	\$ 126,000.00	\$ 126,000		
Demo existing distribution equipment, feeders and power peds	1 LS	\$ 50,000.00	\$ 50,000		
<b>SUBTOTAL HARD CONSTRUCTION COSTS</b>					
BOND / INSURANCE	0.02	\$ 21,815			
PHASING & OFF HOUR WORK	0.25	\$ 272,685			
PERMITTING	N/A	\$ -			
CONTINGENCY	0.10	\$ 109,074			
CONTRACTOR OH & P	0.15	\$ 163,611			
<b>PROBABLE TOTAL PROJECT COST</b>					
					\$ 1,657,924



LONG & ASSOCIATES  
ARCHITECTS / ENGINEERS, INC.

4525 South Manhattan Avenue, Tampa, Florida, 33611-2305 T: (813) 839-0506 F: (813) 839-4616 AAC001624 1828 CGC1511025

www.longandassociates.com

A/E # 17039

CLEARWATER BEACH MARINA ELECTRICAL DISTRIBUTION EVALUATION & FEASIBILITY STUDY  
25 CAUSEWAY BLVD, CLEARWATER BEACH, FL

OPINION OF PROBABLE COST - WEST DOCK POWER DISTRIBUTION SYSTEM

OPTION 2

9/14/2018

COMPONENT DESCRIPTION	AREA	UNIT COST	SUBTOTAL	TOTAL
<b>GENERAL REQUIREMENTS</b>				\$ 131,300
TEMPORARY UTILITIES & FACILITIES	6 MO	\$ 2,500.00	\$ 15,000	
UNDERGROUND UTILITY LOCATION	1 DAY	\$ 900.00	\$ 900	
CLEANING & WASTE MANAGEMENT	25600 SF	\$ 0.75	\$ 19,200	
SUPERVISION (FULL TIME)	6 MO	\$ 7,500.00	\$ 45,000	
PEDESTRIAN PROTECTION	25600 SF	\$ 2.00	\$ 51,200	
SELECTIVE DEMOLITION (INTERIOR)	0 SF	\$ 2.50	\$ -	
<b>SITEWORK/CIVIL</b>				\$ 30,250
CONCRETE DEMO	3200 SF	\$ 0.75	\$ 2,400	
ASPHALT DEMO	0 SF	\$ 0.50	\$ -	
CLEAR & GRUB	0 SF	\$ 0.25	\$ -	
EXCAVATION	475 CY	\$ 6.00	\$ 2,850	
Directional Bore (HDPE conduits)	100 LF	\$ 26.00	\$ 2,600	
NEW CONCRETE PATCH	3200 SF	\$ 7.00	\$ 22,400	
GRAVEL	CY	\$ 80.00	\$ -	
SOD	SY	\$ 15.00	\$ -	
<b>STRUCTURAL</b>				\$ -
N/A				
<b>ELECTRICAL</b>				\$ 408,498
New Switchboard	1 LS	\$ 114,303.00	\$ 114,303	
New Feeders	1 LS	\$ 126,195.00	\$ 126,195	
New Power Pedestals	1 LS	\$ 68,000.00	\$ 68,000	
New Power Panelboards	1 LS	\$ 50,000.00	\$ 50,000	
Demo existing distribution equipment, feeders and power peds	1 LS	\$ 50,000.00	\$ 50,000	
<b>SUBTOTAL HARD CONSTRUCTION COSTS</b>				\$ 570,048
BOND / INSURANCE	0.02	\$ 11,401		
PHASING & OFF HOUR WORK	0.25	\$ 142,512		
PERMITTING	N/A	\$ -		
CONTINGENCY	0.10	\$ 57,005		
CONTRACTOR OH & P	0.15	\$ 85,507		
<b>PROBABLE TOTAL PROJECT COST</b>				\$ 866,473



LONG & ASSOCIATES  
ARCHITECTS / ENGINEERS, INC.

4525 South Manhattan Avenue, Tampa, Florida, 33611-2305 T: (813) 839-0506 F: (813) 839-4616 AAC001624 1828 CGC1511025

www.longandassociates.com

A/E # 17039

**CLEARWATER BEACH MARINA ELECTRICAL DISTRIBUTION EVALUATION & FEASIBILITY STUDY**  
**25 CAUSEWAY BLVD, CLEARWATER BEACH, FL**

OPINION OF PROBABLE COST - EAST DOCK POWER SVS AND DISTR SYSTEM

OPTION 3

9/14/2018

COMPONENT DESCRIPTION	QUANTITY	UNIT	UNIT COST	SUBTOTAL	TOTAL
<b>GENERAL REQUIREMENTS</b>				\$ 110,400	
TEMPORARY UTILITIES & FACILITIES	6	MO	\$ 2,500.00	\$ 15,000	
UNDERGROUND UTILITY LOCATION	1	DAY	\$ 900.00	\$ 900	
CLEANING & WASTE MANAGEMENT	18000	SF	\$ 0.75	\$ 13,500	
SUPERVISION (FULL TIME)	6	MO	\$ 7,500.00	\$ 45,000	
PEDESTRIAN PROTECTION	18000	SF	\$ 2.00	\$ 36,000	
SELECTIVE DEMOLITION (INTERIOR)	0	SF	\$ 2.50	\$ -	
<b>SITWORK/CIVIL</b>				\$ 24,643	
CONCRETE DEMO	2550	SF	\$ 0.75	\$ 1,913	
ASPHALT DEMO	0	SF	\$ 0.50	\$ -	
CLEAR & GRUB	0	SF	\$ 0.25	\$ -	
EXCAVATION	380	CY	\$ 6.00	\$ 2,280	
Directional Bore (HDPE conduits)	100	LF	\$ 26.00	\$ 2,600	
NEW CONCRETE PATCH	2550	SF	\$ 7.00	\$ 17,850	
GRAVEL		CY	\$ 80.00	\$ -	
SOD		SY	\$ 5.00	\$ -	
<b>STRUCTURAL</b>				\$ 109,330	
Steel	14	TONS	\$ 4,500.00	\$ 63,000	
Pile Caps	7	CYD	\$ 800.00	\$ 5,600	
1 1/2"Bar Grading	438	SF	\$ 35.00	\$ 15,330	
Stair w/ Grading Tread	1	EA	\$ 9,000.00	\$ 9,000	
2-Line Hand Rail	95	FT	\$ 40.00	\$ 3,800	
Concrete Piles 6 *30 FT	180	FT	\$ 70.00	\$ 12,600	
<b>ELECTRICAL</b>				\$ 786,669	
New Duke Transformer/Primary Circuit	1	LS	\$ 75,000.00	\$ 75,000	
New Switchboards, Meter Center and Transformer	1	LS	\$ 172,048.00	\$ 172,048	
New Feeders	1	LS	\$ 332,129.00	\$ 332,129	
New Panelboards	1	LS	\$ 41,492.00	\$ 41,492	
New Power Pedestals	1	LS	\$ 116,000.00	\$ 116,000	
Demo existing distribution equipment, feeders and power peds	1	LS	\$ 50,000.00	\$ 50,000	
<b>SUBTOTAL HARD CONSTRUCTION COSTS</b>				\$ 1,031,042	
BOND / INSURANCE	0.02		\$ 20,621		
PHASING & OFF HOUR WORK	0.25		\$ 257,760		
PERMITTING	N/A		\$ -		
CONTINGENCY	0.10		\$ 103,104		
CONTRACTOR OH & P	0.15		\$ 154,656		
<b>PROBABLE TOTAL PROJECT COST</b>				\$ 1,567,183	

# **APPENDIX E -**

## **FIELD SURVEY DRAWINGS**

ARCHITECTURE/ENGINEERING:

LONG & ASSOCIATES

ARCHITECTS / ENGINEERS, INC.  
4525 S. MANHATTAN AVE.  
TAMPA, FLORIDA 33611



AAC001624  
EB 1828  
813/839-0506

# CLEARWATER BEACH MARINA ELECTRICAL DISTRIBUTION EVALUATION

25 CAUSEWAY BLVD, CLEARWATER BEACH, FL 33767  
17039



FIELD SURVEY & DRAWINGS - TASK 1

INDEX OF DRAWINGS

GENERAL


G.0.1 TITLE SHEET

ELECTRICAL


E1.1 OVERALL ELECTRICAL SITE PLAN  
E1.2 REFERENCE SITE PLAN  
E1.3 REFERENCE SITE MAP PLAN  
E2.1 ENLARGED SITE PLAN  
E2.2 ENLARGED SITE PLAN  
E2.3 ENLARGED SITE PLAN  
E2.4 ENLARGED SITE PLAN  
E2.5 ENLARGED SITE PLAN  
E3.1 EXISTING POWER BOLLARD SCHEDULE  
E3.2 PANELBOARD SCHEDULES  
E3.3 ELECTRICAL RISERS  
E3.3A PROPOSED ELECTRICAL RISERS

A/E PROJECT NO: 17039

MARCH 16, 2017



↑  
NORTH  
REGIONAL MAP



PROJECT LOCATION:  
25 CAUSEWAY BLVD  
CLEARWATER BEACH, FL 33767

↑  
NORTH  
LOCAL MAP

# CLEARWATER MARINA ELECTRICAL RENOVATION

FOR THE  
CITY OF CLEARWATER

25 CAUSEWAY BLVD  
CLEARWATER BEACH, FL 33767



NOT FOR  
CONSTRUCTION

No	Date	Issues & Revisions
△		
△		
△		
△		
△		

Phase: FIELD SURVEY & DRAWINGS  
Drawn By: XG  
Checked By: RAR  
Job No: 17039  
Date: 03-16-18


## OVERALL ELECTRICAL SITE PLAN

E1.1



# Clearwater Municipal Marina

- Transient Slips
- Private Slips
- Commercial Slips
- Booth



## CLEARWATER MARINA ELECTRICAL RENOVATION

FOR THE

CITY OF CLEARWATER

25 CASEWAY BLVD

CLEARWATER BEACH, FL 33767

NOT FOR  
CONSTRUCTION


No	Date	Issues & Revisions
△		
△		
△		
△		
△		
△		

Phase: FIELD SURVEY & DRAWINGS  
Drawn By: XG  
Checked By: RAR  
Job No: 1703P  
Date: 03-16-18

REFERENCE SITE  
PLAN

E1.2





## CLEARWATER MARINA ELECTRICAL RENOVATION

FOR THE

CITY OF CLEARWATER


NOT FOR  
CONSTRUCTION



No	Date	Issues & Revisions
△		
△		
△		
△		
△		
△		

Phase: FIELD SURVEY & DRAWINGS  
Drawn By: XG  
Checked By: RAR  
Job No: 17039  
Date: 03-16-18

REFERENCE SITE  
MAP PLAN

E1.3







---

GENERAL NOTES

to	Date	Issues & Revisions

Phase: FIELD SURVEY & DRAWINGS  
Drawn By: XG  
Checked By: RAR  
Job No: 17039  
Date: 03-16-18

ENLARGED  
SITE PLAN



E2.1

## CLEARWATER MARINA ELECTRICAL RENOVATION

FOR THE  
 CITY OF CLEARWATER  
 25 CAUSEWAY BLVD  
 CLEARWATER BEACH, FL 33767


NOT FOR  
CONSTRUCTION

No	Date	Issues & Revisions
△		
△		
△		
△		
△		

Phase: FIELD SURVEY & DRAWINGS  
 Drawn By: XG  
 Checked By: RAR  
 Job No: 17039  
 Date: 03-16-18



ENLARGED  
SITE PLAN


E2.2






### GENERAL NOTES

AREA SHOWN





SERVICE LATERAL W/500 KCMIL CONDUCTORS CIRCUITED TO DUKE ENERGY TRANSFORMER 'UT2'



ENLARGED SITE PLAN


E2.3


No.	Date	Issues & Revisions
△		
△		
△		
△		
△		

Phase: FIELD SURVEY & DRAWINGS  
Drawn By: XG  
Checked By: RAR  
Job No: 17039  
Date: 03-16-18

## CLEARWATER MARINA ELECTRICAL RENOVATION

FOR THE  
CITY OF CLEARWATER  
20 CANEWAY BVD  
CLEARWATER BEACH, FL 33767





## GENERAL NOTES

**LONG & ASSOCIATES**  
**ARCHITECTS / ENGINEERS, INC.**  
4525 S. Manhattan Ave. Tampa, FL 33611-2305  
T: (813) 839-0506 F: (813) 839-4616 AAC001624 CCC01511025  
www.longassociates.com  
THIS DOCUMENT CONTAINS UNCLASSIFIED INFORMATION SUBJECT TO AUTOMATIC DISSEMINATION  
WHICH THE DRAFTS NOTIFICATION COPIES OF THIS DRAWING IS FOR INFORMATION PURPOSES ONLY.

CLEARWATER MARINA  
ELECTRICAL RENOVATION

FOR THE  
CITY OF CLEARWATER  
25 CAUSEWAY BLVD  
CLEARWATER BEACH, FL 33767

NOT FOR  
CONSTRUCTION

No	Date	Issues & Revisions
△		
△		
△		
△		
△		


Phase: FIELD SURVEY & DRAWINGS  
Drawn By: XG  
Checked By: RAR  
Job No: 17039  
Date: 03-16-18

ENLARGED  
SITE PLAN

E2.4

Q11-00400-KOBS1703504-AUDCANE25 Aug Sep 17, 2018 3:38pm

## **GENERAL NOTES**



# CLEARWATER MARINA ELECTRICAL RENOVATION

**CITY OF CLEAR SPRINGS**

25 CALIFORNIA BLVD

THIS DOCUMENT IS CONFIDENTIAL MATERIAL. ANY DISCLOSURE, UNAUTHORIZED USE, OR REPRODUCTION OR REPRODUCTION WITHOUT THE EXPRESSED WRITTEN CONSENT OF LUCING & ASSOCIATES IS PROHIBITED. ALL RIGHTS RESERVED.

**NOT FOR  
CONSTRUCTION**

<u>Job</u>	<u>Date</u>	<u>Issues &amp; Revisions</u>
1		
2		
3		
4		
5		
6		
7		


A KEYPLAN  
SCALE: NTS

ENLARGED  
SITE PLAN

E2.5

CLEARWATER BEACH MARINA BOAT SHORE DOCK POWER BOLLARD SCHEDULE								
POWER BOLLARD ID#	PLUMBING (HOSE BIBB)	SIGNAL (SERVICE PROVIDER OUTLET)	ELECTRICAL					REMARKS
			20/1 RECEPTACLE	30/1 RECEPTACLE	50/2 RECEPTACLE	METERED BOLLARD	BUILT-IN LIGHT	
2				2		X		
3				1		X		
A			2		2?	X		
B			1	2		X		
C				2		X		
D								MOUNTED ON WALL
E								
6								
F				1		X		
10C				1		X		
19			2	2		X		
20			2			X		
21			2	2		X		
22			2	2		X		
23			2	2		X		
24			2	2		X		
25			2	2		X		
26			2	2		X		
27			2	2		X		
28			2	2		X		
29			2	2		X		
30			2	2		X		
31			2	2		X		
32			4	2		X		
33			2	2		X		
34			2	2		X		
35				1	1	X		
36			2	2		X		
37			2	2		X		
38			2	2		X		
39			1	1	1	X		
40			2	2		X		
41			2	2		X		
42			2	2		X		
43			2	2		X		
44			2	2		X		
45			3	2		X		
46			2	2		X		
47			2	2		X		
48			1	2				
G			2	1				
I			1	1				
H								CANT OPEN
J			1	1				
K			1	1				
L			1	2				NO BOLLARD
M								
N(57)			2	2		X		
149	X	X		1	1	X X		WITH 148
150	X	X		2	2	X X		
M1	X			2	2	X X		
M2	X			2	2	X X		
M3	X			2	2	X X		
M4	X			2	2	X X		
M5		TV	1	1	1	X X		
M6		TV	1	1	1	X X		
M7	X		1	1	1	X X		
M8	X		1	1	1	X X		
M9	X		1	1	1	X X		
M10	X		2	2	1	X X		ONE SIDE IS M44
M11	X		1	1	2	X X		ONE SIDE IS M43
M12	?	?	2	2	?	?		IN 106 & 108
M13	?	?	1	1	2	?	?	IN 101 & 102
M14	X		2	2		X X		
M15	X		2	2		X X		
M16	X		1	1	1	X X		
M17	X		1	1	2	X X		
M18	X		1	1	1	X X		
M19	X		1	1	1	X X		
M20	X	X	2	2		X X		
M21	X	X	1	1	1	X X		
M22	X	X	1	1	1	X X		
M23	X		1	1	17	X X		
M24			1	1	1	X X		
M25			1	1	1	X X		
M26		X			2	X X		NO PICS
M27		X						
M28	X	?		1	1	X X		
M29	X	X		1	1	X X		
M30	X			1	1	X X		
M31	X	X		1	1	X X		

CLEARWATER BEACH MARINA BOAT SHORE DOCK POWER BOLLARD SCHEDULE								
POWER BOLLARD ID#	PLUMBING (HOSE BIBB)	SIGNAL (SERVICE PROVIDER OUTLET)	ELECTRICAL					REMARKS
			20/1 RECEPTACLE	30/1 RECEPTACLE	50/2 RECEPTACLE	METERED BOLLARD	BUILT-IN LIGHT	
M32			X					
M33			X					
M34			X					
M35			X	?				
M36			X	?	1			
M37			X		1			
M38	X		X		1			
M39	X	X			1			
M40	X				1			
M41			X		2			
M42			X	2	1			
M43			X	2	2			
M44				2	1			
M45					1			
M46	X		X		1			
M47	X		X		2			
M48	X		X		1			
M49	X	X			1			
M50	X		X		2			
M51	X		X		2			
M52	X		X		2			
M53	X		X		2			
M54	X				2			
M55	X				1			
M56	X				1			
M57	X				1			
M58	X				1			
M59	X				1			
M60		TV		1?	1			
M61		TV		1?	1			
M62	X				2			
M63	X				2			
M71A			X		1?			
M71B			X		1?			
M72A			X		1?			
M72B			X		1?			
NN01			X		2			
NN02	X		X		1			
NN03					1	4	2	2
101	X		X		1			WITH M13
102	X?	X			2	?	?	?
103	X				2			
104	X				2			
105	X				2	?	?	WITH M12, T126
106	X		X		1			
107	X				2			
108	X				2			
109	X				2			
110								



EXISTING DPD (DUMPSTER AREA)								MICs MUL. 100	AMPS
BRANCH LOAD	AMPS	CBP	A	B	C	CBP	AMPS	BRANCH LOAD	
BACKED MCB	-	1003	1	-	-	2	1003	-	DUMPSTER HYDRAULIC PUMP
-	-	-	-	-	-	-	-	-	-
SERVICE RECEPTACLE	-	20H	7	-	-	8	20H	1	PHOTOCELL/LIGHTING
SPACE	-	-	11	8	-	10	-	-	SPACE
SPACE	-	-	11	11	-	12	-	-	SPACE
SPACE	-	-	11	13	-	14	-	-	SPACE
SPACE	-	-	11	15	-	16	-	-	SPACE
SPACE	-	-	11	17	-	18	-	-	SPACE
SPACE	-	-	11	18	-	20	-	-	SPACE
SPACE	-	-	11	21	-	22	-	-	SPACE
SPACE	-	-	11	23	-	24	-	-	SPACE
SPACE	-	-	11	23	-	26	-	-	SPACE
SPACE	-	-	11	27	-	28	-	-	SPACE
SPACE	-	-	11	28	-	30	-	-	SPACE
TOTAL AMPS:	APIH =	BPH =	CPH =						
LOADS	COMM KVA	FACTOR	DMD KVA	DIVERSITY		DES KVA			
LIGHTING	-	x	=	-	x	1.00	=	-	REMARKS:
RECEP	-	x	=	-	x	1.00	=	-	REMARKS:
ARMCHAIRS	-	x	1.25	=	-	x	1.00	=	-
COOLING	-	x	=	-	x	1.00	=	-	
HEATING	-	x	1.00	=	-	x	1.00	=	-
MISC EQUIP	-	x	1.00	=	-	x	1.00	=	-
EXI FANS	-	x	1.25	=	-	x	1.00	=	-
WATER HEAT	-	x	1.25	=	-	x	1.00	=	-
FUTURE	-	x	1.00	=	-	x	1.00	=	-
TOTALS	KVA		-	KVA		-	KVA		
■ GROUND BAR									
FEEDER: EXISTING									



NOT FOR  
CONSTRUCTION

No	Date	Issues & Revisions
△		
△		
△		
△		
△		
△		

Phase: FIELD SURVEY & DRAWINGS  
 Drawn By: XG  
 Checked By: RAR

PANELBOARD  
SCHEDULES

E3.2



FEEDER TAP BOX "FT1" CB SCHEDULE	
FEEDER CB SIZE (AMPS/POLES)	LOADS SERVED
600	?
300	?
301	?
201	?
202	?
203	?
204	?
205	?
206	?
207	?
208	?
209	?
210	?
211	?
212	?
213	?
214	?
215	?
216	?
217	?
218	?
219	?
220	?
221	?
222	?
223	?
224	?
225	?
226	?
227	?
228	?
229	?
230	?
231	?
232	?
233	?
234	?
235	?
236	?
237	?
238	?
239	?
240	?
241	?
242	?
243	?
244	?
245	?
246	?
247	?
248	?
249	?
250	?
251	?
252	?
253	?
254	?
255	?
256	?
257	?
258	?
259	?
260	?
261	?
262	?
263	?
264	?
265	?
266	?
267	?
268	?
269	?
270	?
271	?
272	?
273	?
274	?
275	?
276	?
277	?
278	?
279	?
280	?
281	?
282	?
283	?
284	?
285	?
286	?
287	?
288	?
289	?
290	?
291	?
292	?
293	?
294	?
295	?
296	?
297	?
298	?
299	?
300	?
301	?
302	?
303	?
304	?
305	?
306	?
307	?
308	?
309	?
310	?
311	?
312	?
313	?
314	?
315	?
316	?
317	?
318	?
319	?
320	?
321	?
322	?
323	?
324	?
325	?
326	?
327	?
328	?
329	?
330	?
331	?
332	?
333	?
334	?
335	?
336	?
337	?
338	?
339	?
340	?
341	?
342	?
343	?
344	?
345	?
346	?
347	?
348	?
349	?
350	?
351	?
352	?
353	?
354	?
355	?
356	?
357	?
358	?
359	?
360	?
361	?
362	?
363	?
364	?
365	?
366	?
367	?
368	?
369	?
370	?
371	?
372	?
373	?
374	?
375	?
376	?
377	?
378	?
379	?
380	?
381	?
382	?
383	?
384	?
385	?
386	?
387	?
388	?
389	?
390	?
391	?
392	?
393	?
394	?
395	?
396	?
397	?
398	?
399	?
400	?
401	?
402	?
403	?
404	?
405	?
406	?
407	?
408	?
409	?
410	?
411	?
412	?
413	?
414	?
415	?
416	?
417	?
418	?
419	?
420	?
421	?
422	?
423	?
424	?
425	?
426	?
427	?
428	?
429	?
430	?
431	?
432	?
433	?
434	?
435	?
436	?
437	?
438	?
439	?
440	?
441	?
442	?
443	?
444	?
445	?
446	?
447	?
448	?
449	?
450	?
451	?
452	?
453	?
454	?
455	?
456	?
457	?
458	?
459	?
460	?
461	?
462	?
463	?
464	?
465	?
466	?
467	?
468	?
469	?
470	?
471	?
472	?
473	?
474	?
475	?
476	?
477	?
478	?
479	?
480	?
481	?
482	?
483	?
484	?
485	?
486	?
487	?
488	?
489	?
490	?
491	?
492	?
493	?
494	?
495	?
496	?
497	?
498	?
499	?
500	?
501	?
502	?
503	?
504	?
505	?
506	?
507	?
508	?
509	?
510	?
511	?
512	?
513	?
514	?
515	?
516	?
517	?
518	?
519	?
520	?
521	?
522	?
523	?
524	?
525	?
526	?
527	?
528	?
529	?
530	?
531	?
532	?
533	?
534</	

## CLEARWATER MARINA ELECTRICAL RENOVATION

FOR THE  
CITY OF CLEARWATER  
25 CAUSEWAY BLVD  
CLEARWATER BEACH, FL 33763

NOT FOR  
CONSTRUCTION  
ROBERT A. RACE II, P.E.  
PE 51483

No	Date	Issues & Revisions
△		
△		
△		
△		
△		




Phase: FIELD SURVEY & DRAWINGS  
 Drawn By: XG  
 Checked By: RAR  
 Job No: 17039  
 Date: 03-16-18

PROPOSED NEW  
ELECTRICAL RISERS


E3.3A

PROPOSED WEST AND MAIN DOCK  
ELECTRICAL RISER  
1 SCALE: NTS

DRY TYPE TRANSFORMER SCHEDULE							
DSGN	PRIMARY VOLTAGE	SECONDARY VOLTAGE	KVA	PHASE	REMARKS	TYPE	REMARKS
TE	208 Delta	240Y/133 WYE	750	3	PAD MTD	GP	PROVIDE NEMA-3R WEATHERSHIELD AND STAINLESS STEEL ENCLOSURE PROVIDE PRIMARY/SECONDARY WINDING TAPS. ANSI/NEMA ST20.
TW	208 Delta	240Y/133 WYE	750	3	PAD MTD	GP	PROVIDE NEMA-3R WEATHERSHIELD AND STAINLESS STEEL ENCLOSURE PROVIDE PRIMARY/SECONDARY WINDING TAPS. ANSI/NEMA ST20.




Section/Township/Range (08-29-15)  
1-foot Elevation Contour Lines  
2017 Imagery




0 200 400 600 800 1000  
Feet  
Contour Interval = 1 foot  
Vertical Datum = Mean Sea Level  
Orthorectified Imagery

This map is provided by the Southwest Florida Water Management District for the use of its employees, contractors, and consultants. It is not to be reproduced or distributed outside the SWFWMD without prior written permission from the SWFWMD. This map is not to be used for surveying or engineering purposes. It is intended to be used for general planning and monitoring purposes only. The SWFWMD does not guarantee the accuracy of the data contained in this map. The SWFWMD is not responsible for any errors or omissions in the data contained in this map.

SOUTHWEST FLORIDA  
WATER MANAGEMENT DISTRICT  
This map is provided by the Southwest Florida Water Management District for the use of its employees, contractors, and consultants. It is not to be reproduced or distributed outside the SWFWMD without prior written permission from the SWFWMD. This map is not to be used for surveying or engineering purposes. It is intended to be used for general planning and monitoring purposes only. The SWFWMD does not guarantee the accuracy of the data contained in this map. The SWFWMD is not responsible for any errors or omissions in the data contained in this map.






**APPENDIX F –**


**ELECTRICAL RISERS**

**&**


**VOLTAGE DROP CALCULATIONS**



卷之三



WEST DOCK ELECTRICAL RISER



## EAST DOCK ELECTRICAL RISER

