


MODIFIED CURB OR TYPE 1 CURB PLAN VIEW

N.T.S.


NOTES:

1. Non traffic bearing.
 2. When pipe diameter exceeds 30", inlets shall not be used as junction boxes, limit 3 pipes per inlet.
 3. Chamfer all exposed edges $\frac{3}{4}$ ".
 4. All concrete shall be 3,000 psi, with fiber mesh reinforcing.
 5. Center support shall be used on double wing inlets.
- (See INDEX 209, PAGE 2 of 2, DETAIL B).



VALLEY GUTTER CURB PLAN VIEW

N.T.S.



DETAIL "A"

N.T.S.

6/5/15	COMBINED PLAN VIEWS	S.R.
DATE	REVISION DESCRIPTION	APP

CITY OF CLEARWATER
ENGINEERING DEPARTMENT
STORM
DETAILS

WING INLETS FOR
MODIFIED, TYPE I & VALLEY GUTTER CURB
PLAN VIEW

INDEX NO.	PAGE NO.
209	1 OF 2
LATEST REVISION	2/22/2016