



NOTES:

1. Sanitary laterals to be within 10' of center of lot on downhill side of center of lot.
2. Vertical and horizontal clearance between potable water main and sanitary sewer lateral at each intersection to be per FDEP requirements. (See F.A.C. Rule 62-555)

6/27/16	Revised Note 2	R.F.
DATE	REVISION DESCRIPTION	APP

**CITY OF CLEARWATER**  
ENGINEERING DEPARTMENT  
**SANITARY SEWER  
DETAILS**

**SANITARY LATERAL LOCATIONS**

INDEX NO.	PAGE NO.
305	3 OF 3
LATEST REVISION	2/22/2016