



Addendum #1
ITB # 47-20, MOBILE NATURAL GAS TANK SERVICES
8/5/2020

NOTICE IS HEREBY GIVEN that the following addendum serves to provide clarification and to answer the questions received on ITB # 47-20, MOBILE NATURAL GAS TANK SERVICES.

Please note that revisions have been made to Detailed Specifications, Item 5.2 Mobilization. Refer to Answer to Question 3 for information regarding the revision.

Question 1: For staging for emergency services, am I correct in interpreting this as hurricane preparation? If so, are we able to offer staging outside of Pinellas and Pasco Counties if deemed appropriate by storm projection to keep equipment protected to ensure we would be able to dispatch/mobilize as soon as conditions are safe and services are warranted?

Answer to Question 1: Emergency hurricane preparedness and response falls under Item 4.1 Emergency Services. The City approves of all personnel and equipment being staged in a safe location during a severe weather event, available for quick dispatch when conditions have been deemed safe.

Question 2: Historically, have there been any other type noteworthy emergency outage scenarios you feel could become an issue again that we should make a point to address in our bid?

Answer to Question 2: Historical emergencies include line breaks, construction damage to the system, extreme demand as a result of a severe cold weather event, and other harsh weather conditions (hurricane, tropical storm, tornado).

Question 3: Regarding the as needed basis, can you please elaborate. Is this for planned outage periods such as pipeline maintenance and inspection? If so, does the 2 hour response window apply to this or is it scheduled further in advance and the 2 hour response window applies to the scheduled time period? If not, can you please explain the application.

Answer to Question 3: "As-needed" services refers to various types of planned operations maintenance events. After further consideration, the City has decided to extend the mobilization window for Project Sites and as-needed services from twenty-four (24) hours to seven (7) calendar days. Therefore, If an event is planned, a non-emergency, or a designated Project Site, the City expects the contractor to be on-site within seven (7) calendar days of notification. Non-planned events are categorized as Emergency Services for this solicitation and the two (2) hour response time applies (ex. line breaks, low gas pressure).

End of Questions and Answers

End of Addenda