



**ADDENDUM NO. 3**

**For**

**20-0012-UT WTP3 - EAST DOME AND AERATOR AND MISC. IMPROVEMENTS  
Clearwater, Florida**

**DATE: April 5, 2022**  
**SUBJECT: Addendum No. 3**  
**TO: Prospective Bidders and Others Concerned**

---

Bidders on the above project are hereby notified that the following Addenda are made to the Contract Documents:

1. **Question:** Question was raised during site visit: Inquired if the manways were to be replaced or just the gasket.
2. **Answer:** Upon review of the specs while on site confirmed it is just the gaskets. Please refer to work item #8 on page 247 of the specs.

**Addendum 3  
Page 1**