

**ADDENDUM NO. 1**

**DATED: November 4, 2020**

**TO THE DRAWINGS AND PROJECT MANUAL FOR:**

**PROJECT: Morningside Tennis Court Lighting**  
**PROJECT NO. 19-0035-PR**

<b>PREPARED BY:</b>	<b>PARKS AND RECREATION DEPARTMENT</b> <b>100 S. MYRTLE AVE.</b> <b>CLEARWATER, FLORIDA 3375</b> <b>PHONE: 727-562-4856</b> <b>FAX: 727-562-4825</b>	<b>ADVANCE ENGINEERING &amp; DESIGN</b> <b>3931 68<sup>TH</sup> NORTH</b> <b>PINELLAS PARK, FLORIDA 33781</b>
---------------------	--	---

**THIS ADDENDUM NO. 1 ISSUED TO CLARIFY, BID MEETNIG, SIGN IN SHEET AND QUESTIONS AND ANSWERS TO BIDDING DOCUMENTS FOR MORNINGSIDE TENNIS COURT LIGHTING - PROJECT NO. 19-0035-PR OF THE CONTRACT DOCUMENTS FOR THIS WORK, THIS ADDENDUM CONSTITUTES A PART OF THE CONTRACT DOCUMENTS. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE PROPOSAL FORM.**

**A. Discussed items at Pre-Bid Meeting Agenda Minutes dated October 28, 2020 1:30 PM.**

- 1 See attached Recommended Pre-Bid Meeting Agenda Minutes – 6 pages.

**B. Attached Pre bid sign in sheet – one page**

**C. Questions & Responses:**

1. Direct purchase of MUSCO Lighting System by Owner are we to include cost of MUSCO Lighting System in our Bid?  
**Response:** Yes, prospective bidders shall include MUSCO Lighting System in his proposal and all applicable sales tax in his proposal.
2. At Morningside Tennis, the light poles on the South side of the courts have very limited access from outside of the courts. It will be necessary to drive a crane truck onto the courts to set the poles.
  - a. Given that the courts were previously lit with light poles, were those poles maintained with a bucket truck driving on the courts?  
**Response:** The original sport lighting access were not across tennis court, but on the south side of the tennis court fencing, there was very little landscaping, playground was not existing and sidewalk not an issue.
  - b. Will the winning bidder be allowed to drive a truck on the courts, and are there any provisions in place to refinish the courts after the lighting installation is complete?  
**Response:** There are no current plans to refinish the tennis courts, however the Owner will make arrangements to remove portion of fencing to allow access from north side across tennis courts court surface and minimize numerous times crossing tennis courts and take care not to damage tennis court surface.
  - c. Will it be acceptable to install the control cabinet for the lighting on the South East corner of the courts on the light pole installed there or on a separate concrete post? Or will installation of the control cabinet be required to be located at the point of service?  
**Response:** Contractor shall install electrical panels as shown on contract drawings and no deviation from permitted drawings.
3. Regarding Prequalification we have a continuing contact with the City of Clearwater do we need to prequalify again.  
**Response:** All contractor shall contact Construction Contract and Procurement Specialist Laura Davis at (727) 562-4509 or [Laura.Davis@myclearwater.com](mailto:Laura.Davis@myclearwater.com). to confirm you are prequalified. Even though you may have a current city contract you may not be prequalified, or it has expired. Your prequalification must be submitted, Pre-qualification applications are due on Wednesday, November 11, 2020, two weeks (ten business days) before the bid opening. No exceptions.
4. Will the city accept tennis court lighting equal to MUSCO Sport Lighting?  
**Response:** Please see Morningside Tennis Performance Spec 2020 Sport Lighting must be equal to this technical specification in every aspect; Lighting Performance, Environmental Light Control, Sport Lighting System Construction, Electrical, Structural Parameters, Control, Field Quality Control, 25 year Warranty and Guarantee of entire system, Maintenance Monitoring 25 years repair and replacement of luminaires. Bidder must provide information of what is the lighting equal manufacture and information about sport lighting system they propose at time of submission of their bid proposal if it is other than MUSCO Sport Lighting System as specified. If bidder fails to provide this equal sport lighting system and is successful bidder and awarded the contract shall install MUSCO Sport Lighting System and other manufacture will not be accepted in the submittal process.

**End of Addendum No. 1**