

**ADDENDUM NO. 1**  
**FOR**  
**MS WRF CHLORINE CONTACT CHAMBER**  
**PROJECT # 18-0060-UT**

DATE: February 9, 2021

SUBJECT: Clarifications

TO: Prospective Bidders and Others Concerned

---

Bidders on the above project are hereby notified the following Addenda are made clear to the Contract Documents:

Contract Specifications:

**1. Section 09901 – PROTECTIVE LINING SYSTEM FOR INTERIOR CONCRETE**

*09901-12: AREAS TO RECEIVE COATING/LINING SYSTEM*

*Updated table to include coating thickness and included additional detail.*

MULTI-COMPONENT MODIFIED POLYMER COATING			
Area Description	Surfacer Mortar	Primer Coat	Final Coat
Inner Chlorine Contact Chamber (CCC): the wall adjacent to the Filter Building and the weir wall.	Product: GML Mortar  Thickness: 125-250 mils	Product: Green Monster Primer  Thickness: 6 mils	Product: Green Monster Liner  Thickness: 125 mils, 15-20 mils per pass

**END OF ADDENDUM #1**

**THE CITY OF CLEARWATER**  
**PINELLAS COUNTY, FLORIDA**  
**By: /s/William B. Horne, II**  
**City Manager**