



Addendum #1
ITB #34-22, Pump, Transport and Dispose of Leachate
July 26, 2022

NOTICE IS HEREBY GIVEN that the following addendum serves to provide clarification and to answer the questions received on ITB #34-22, Pump, Transport and Dispose of Leachate.

Question 1: Regarding the product to be hauled: Suspended solids, sediment, and solids in solution are fine, we just cannot accept soda cans, wood, plastics, paper etc. Please confirm the product is liquid, and no plastics, soda cans, rocks, wood etc. will be pumped into our tankers.

Answer to Question 1: Confirmed; no plastic, soda cans, rocks, nor wood will be pumped into the tankers

Question 2: The bid form asks "What percentage of solids can be taken per trip, if any?" Please confirm you mean suspended solids, solids in solution, sediment etc., and do not mean plastics, soda cans, paper wood etc.

Answer to Question 2: Reference Answer to Questions 1 above. The bid pertains to suspended solids, solids in solution, and sediment.

Question 3: Does the facility have a pump to load our tanker, or do we need to provide a pump to load our tanker?

Answer to Question 3: The facility does not have a pump to load the tanker. The transporter will need to have a pump and all attachments.

Question 4: What is the minimum # Gallons contractor might be asked to haul for one load?

Answer to Question 4: The City requires tanks to be pumped when they are ½ to ¾ full. An estimated one thousand (1,000) gallons would be the minimum collected in a single load.

End of Questions and Answers

All other dates and terms and conditions remain the same in this Invitation to Bid.

End of Addenda