

ADDENDUM NO. 6
Marshall Street-Northeast WRF Crack Sealing (FDEP)

PROJECT NUMBER: 18-0046-UT

DATE: June 10, 2020

SUBJECT: Addendum No. 6

TO: Prospective Bidders and Others Concerned

This addendum is issued to modify the previously issued bid documents and/or given for information purposes and is hereby made a part of the bid documents. Please attach this addendum to the documents in your possession.

Bidders on the above project are hereby notified that the following Addenda are made to the Contract Documents:

1. Question: Will Owner require Fixed Project Signs for both locations?

Answer: Yes, (1) fixed project sign shall be provided at each location per Specification Section IV page 1 of 105.

2. Question: Will conduit be moved by Owner at Owner's expense?

Answer: Refer to Specification Section 01025, 1.01.E.14-16, which lists that no separate payment will be made for this work. Refer to general note 1-5 on drawing no. G-00-101 for conduit temporary adjustment by the contractor.

3. Question: With two locations, is the mobilization amount limited to 5% of total bid per bid documents? Section 01025, 3.01, 1.0.

Answer: Correct, limit mobilization to 5% per referenced Specification Section.

4. Question: Is Builders Risk Insurance required for this project?

Answer: Refer to 5.2.6 BUILDER'S RISK INSURANCE per Section III page 10.

5. Question: Contract time is how long for work to be performed?

Answer: Contract period is 75 consecutive calendar days per Specification Section IV page 1 of 105.

6. Question: On the bid sheet, “Shallow Patch Repair” is to what depth? I.E. up to 1”?
“Deep Patch Repair” > than 1”?

Answer: Refer to repair details on Drawing No. G-00-101. Shallow patch repair shall be up to 2” maximum before the existing rebar is encountered. Deep patch repair shall be for patches deeper than 2” as shown in Detail C on G-00-101.

END OF ADDENDUM #6