



Addendum #3
ITB #31-21, Pump, Transport and Dispose of Leachate
April 7, 2021

NOTICE IS HEREBY GIVEN that the following addendum serves to provide clarification and to answer the questions received on ITB # 31-21, Pump, Transport and Dispose of Leachate

Question 1: Do you wait until the tanks are full to call for a pumping?

Answer to Question 1: No, we do not wait till the tank is full. Currently, the City will pump the tanks when they are ½ to ¾ full.

Question 2: Can the contractor swing by on a regular schedule?

Answer to Question 2: No, since the leachate varies month to month, a regular schedule will not be considered at this time and services shall be performed on an as-needed basis.

Question 3: How many emergency calls were dispatched?

Answer to Question 3: Since the transfer station opened in May of 2020, the City has had two (2) emergency or "high priority" pumpings that were attributed to weather conditions.

Question 4: How are the pumping coordinated with the contractor?

Answer to Question 4: Refer to MINIMUM QUALIFICATIONS, 2. SCOPE OF SERVICES, A. GENERAL REQUIREMENTS, Item 2., page 15.

End of Questions and Answers

Additional Clarification: This is the final addenda for this solicitation. No further questions will be accepted.

All other dates and terms and conditions remain the same in this Invitation to Bid.

End of Addenda