



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.
Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR. (VIO = Visual Inspection Only)

Certificate Reference

4 Fire Road, Broxburn, EH52 1DD

Certificate No: 4 Fire Road, Broxburn, EH52 1DD

Engineers Details	Installation Details	Client Details
Trading Title West Lothian Gas Ltd Address 18 Mauldeth Rd Broxburn Post Code: EH52 6FB	Installation Address The Tenant 4 Fire Road Broxburn Post Code: EH52 1DD	Client Citizen Housing Group Ltd Address Lakeside 4040 Solihull Pkwy Birmingham Post Code: B37 7YN
Gas Safe No: 7777777 Telephone No: 07961768920	Telephone No: NA	Telephone No: 0300 790 6555

Appliance Details					Inspection Details													
	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/VIO)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar)	Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen Cupboard	Combi	Worcester	30CDi	9.29 %	287 ppm	RS	Yes	0.0032	Yes	NA	30 kW	Yes	Pass	Pass	Pass	No	Yes
2	kitchen	cooker	Valor	unknown	NA	NA	FL	Yes	NA	No		NA	Yes	Yes	N/A	N/A	No	Yes
3																		
4																		
5																		

	Faults/Notes	Remedial Work Taken	Warning Notice Fixed
1			
2			
3			
4			
5			

Emergency Control Valve Accessible: Gas Tightness Satisfactory: Gas Installation Pipework Visual Inspection Satisfactory: Number of Appliances Tested: Equipotential Bonding: NEXT INSPECTION DUE ON OR BEFORE: Installation Pass: CO Alarm fitted & working? Smoke alarm fitted & working?	YES YES YES 2 YES 03/05/2027 YES YES YES	Signatures Report Issued By: Name: <u>Richard Dick</u> Signed: <u>Richard Dick</u> Date: 03/05/2026 Report Received By: Name: <u>Citizen Housing Group Ltd</u> Signed: _____ Date: 03/05/2026	Gas Safe Registration No: 7777777 Licence No: 6666666
--	---	--	--