



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR. (VIO = Visual Inspection Only)

Certificate Reference
1 Pass Lane, EH52 1AA
Certificate No: 1 Pass Lane, EH52 1AA

Engineers Details	Installation Details	Client Details
Trading Title West Lothian Gas Ltd Address 18 Mauldeth Rd Broxburn Post Code: EH52 6FB	Installation Address The Tenant 1 Pass Lane Broxburn Post Code: EH52 1AA	Client Citizen Housing Group Ltd Address Lakeside 4040 Solihull Pkwy Birmingham Post Code: B37 7YN
Gas Safe No: 1234567 Telephone No: 07961768920	Telephone No: NA	Telephone No: 0300 790 6555

Appliance Details					Inspection Details													
	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/VIO)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar)	Heat Input (KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	kitchen	combi boiler	Worcester	28i Junior	10.06 %	66 ppm	RS	Yes	0.0019	Yes	20 mbar	27.6kW	Yes	Pass	Pass	Pass	No	Yes
2																		
3																		
4																		
5																		

	Faults/Notes	Remedial Work Taken	Warning Notice Fixed
1			
2			
3			
4			
5			

Emergency Control Valve Accessible:
Gas Tightness Satisfactory:
Gas Installation Pipework Visual Inspection Satisfactory:
Number of Appliances Tested:
Equipotential Bonding:
NEXT INSPECTION DUE ON OR BEFORE:
Installation Pass:
CO Alarm fitted & working?
Smoke alarm fitted & working?


YES
YES
YES
1
YES
04/05/2027
YES
YES
YES

Signatures		
Report Issued By:		
Name: Test Engineer QA	Signed: Test Engineer QA	Date: 04/05/2026
Report Received By:		
Name: Citizen Housing Group Ltd	Signed:	Date: 04/05/2026

Gas Safe Registration No:
1234567
Licence No:
9876543



GAS METER



BOILER FRONT