

**Installation Details**

Installation Address: Stephen Martin  
29 Edward Road  
Keresley  
Coventry  
Postcode: CV6 2GS

**Client Details**

Client Address: Stephen Martin  
29 Edward Road  
Keresley  
Coventry  
Postcode: CV6 2GS

**Appliance Details**

CO/CO2 Ratio: 0.0031 Service: YES Breakdown: N/A CO2 Reading: 9.3 % CO Reading: 290 ppm

Boiler Make: Baxi Boiler Model: 830 Combi Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

**Preliminary Checks**

**Satisfactory** YES NO NA

|                                                        |     |  |  |
|--------------------------------------------------------|-----|--|--|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES |  |  |
| Ventilation Size/H-L                                   | YES |  |  |
| Water/Fuel - Sound                                     | YES |  |  |
| Electrically Fused                                     | YES |  |  |
| Correct Valving Arrangement                            | YES |  |  |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |  |  |
| Boiler/Plant room Clean & Clear                        | YES |  |  |

**Service Checks**

**Satisfactory**

|                      |     |  |  |
|----------------------|-----|--|--|
| Heat Exchanger       | YES |  |  |
| Ignition             | YES |  |  |
| Gas Valve            | YES |  |  |
| Fan                  | YES |  |  |
| Safety Device        | YES |  |  |
| Control Box          | YES |  |  |
| Burner & Pilot       | YES |  |  |
| Fuel Pressure & Type | YES |  |  |

**Service Operations**

**Satisfactory**

|                                            |     |  |    |
|--------------------------------------------|-----|--|----|
| Burner Washed & Clean                      |     |  |    |
| Pilot Assembly Cleaned & Adjusted          |     |  |    |
| Ignition System Cleaned & Adjusted         |     |  |    |
| Burner Fan & Airways Cleaned               |     |  |    |
| Heat Exchanger/Flueways Clean & Clear      |     |  | NA |
| Fuel & Electrical Supply Connected & Sound | YES |  |    |
| Interlocks in Place                        |     |  |    |

**Additional Notes**

cleaned condense trap and filter

**Spares Required**

none

**Engineers Details**

Trading Title: Coventry Gas Services Ltd  
47 Alspath Road  
Meriden  
Postcode: CV7 7LU

Gas Safe Number 927997 Time of Arrival: 11:43 am  
Gas ID Number 5739462 Time of Departure: 11:43 am  
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Wed-18-Dec-2024

Report Received By Name: Signature: Date: Wed-18-Dec-2024