

Installation Details

Installation Address: Kathryn Taylor
7 Home Close
Coventry
Postcode: CV8 3JD

Client Details

Client Address: Kathryn Taylor
7 Home Close
Coventry
Postcode: CV8 3JD

Appliance Details

CO/CO2 Ratio: 0.0018 Service: YES Breakdown: N/A CO2 Reading: 10.5 % CO Reading: 188 ppm

Boiler Make: Worcester Boiler Model: Greenstar 30CDI system Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory YES NO NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted	YES		
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear	YES		
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

cleaned filter and condense trap

Spares Required**Engineers Details**

Trading Title: Coventry Gas Services Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 927997 Time of Arrival: 02:51 pm
Gas ID Number 5545563 Time of Departure: 02:51 pm
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Thu-17-Oct-2024

Report Received By Name: Signature: Date: Thu-17-Oct-2024