

Gas Service/Breakdown Record

Certificate Ref.

121 Montague Road 2024

Certificate No 121 Montague Road 2

Installation DetailsInstallation
Address:Kulbinder Singh Lehl
121 Montague Road
Smethwick

Postcode: B66 4PW

Client DetailsClient
Address:Kulbinder Singh Lehl
121 Montague Road
Smethwick

Postcode: B66 4PW

Appliance DetailsCO/CO2
Ratio:

0.0007

Service:

YES

Breakdown:

N/A

CO2

Reading:

8.8 %

CO Reading:

62 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 30i Erp

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks**Satisfactory****YES****NO****NA**

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks**Satisfactory**

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations**Satisfactory**

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

Cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

12:17 pm

Gas ID Number

5545563

Time of

Departure:

12:17 pm

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Fri-11-Oct-2024

Report Received By

Name:

Signature:

Date:

Fri-11-Oct-2024