

# Gas Service/Breakdown Record

Certificate Ref.

8 Arthur Harris Close 2024

Certificate No 8 Arthur Harris Close :

**Installation Details**

Installation Address: Gurps Mankoo  
8 Arthur Harris Close  
Smethwick

Postcode: B66 4NX

**Client Details**

Client Address: Gurps Mankoo  
8 Arthur Harris Close  
Smethwick

Postcode: B66 4NX

**Appliance Details**CO/CO2  
Ratio:

0.0008

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.0 %

CO Reading:

68 ppm

Boiler Make:

Vaillant

Boiler Model:

ECOTEC PLUS 418 VU186/2

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

**Preliminary Checks****Satisfactory**

YES

NO

NA

|                                                        |     |  |  |
|--------------------------------------------------------|-----|--|--|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES |  |  |
| Ventilation Size/H-L                                   | YES |  |  |
| Water/Fuel - Sound                                     | YES |  |  |
| Electrically Fused                                     | YES |  |  |
| Correct Valving Arrangement                            | YES |  |  |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |  |  |
| Boiler/Plant room Clean & Clear                        | YES |  |  |

**Service Checks****Satisfactory**

|                      |     |  |  |
|----------------------|-----|--|--|
| Heat Exchanger       | YES |  |  |
| Ignition             | YES |  |  |
| Gas Valve            | YES |  |  |
| Fan                  | YES |  |  |
| Safety Device        | YES |  |  |
| Control Box          | YES |  |  |
| Burner & Pilot       | YES |  |  |
| Fuel Pressure & Type | YES |  |  |

**Service Operations****Satisfactory**

|                                            |     |  |    |
|--------------------------------------------|-----|--|----|
| Burner Washed & Clean                      |     |  |    |
| Pilot Assembly Cleaned & Adjusted          |     |  |    |
| Ignition System Cleaned & Adjusted         |     |  |    |
| Burner Fan & Airways Cleaned               |     |  |    |
| Heat Exchanger/Flueways Clean & Clear      |     |  | NA |
| Fuel & Electrical Supply Connected & Sound | YES |  |    |
| Interlocks in Place                        |     |  |    |

**Additional Notes**

cleaned and serviced magnaclean

**Spares Required**

none

**Engineers Details**

Trading Title: Coventry Gas Services Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of  
Arrival:

10:54 am

Gas ID Number

5545563

Time of

Departure:

10:54 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Fri-11-Oct-2024

Report Received By

Name:

Andrew King-Page

Signature:



Date:

Fri-11-Oct-2024