

Gas Service/Breakdown Record

Certificate Ref.

Throckmorton 2024

Certificate No Throckmorton 2024

Installation DetailsInstallation
Address:Steve Day
23 Throckmorton Rd
Alcester
Warks

Postcode: B496QA

Client DetailsClient
Address:Steve Day
23 Throckmorton Rd
Alcester
Warks

Postcode: B496QA

Appliance DetailsCO/CO2
Ratio:

0.0008

Service:

YES

Breakdown:

N/A

CO2

Reading:

8.6 %

CO Reading:

73 ppm

Boiler Make:

Baxi

Boiler Model:

830 Combi

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks**Satisfactory****YES****NO****NA**

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks**Satisfactory**

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations**Satisfactory**

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

09:43 am

Gas ID Number

5545563

Time of

Departure:

09:43 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Tue-24-Sept-2024

Report Received By

Name:

Signature:

Date:

Tue-24-Sept-2024