

Gas Service/Breakdown Record

Certificate Ref.

75 Ashford Gardens 2024

Certificate No 75 Ashford Gardens 2

Installation Details

Installation Address:

Mr Singh
75 Ashford Gardens
Leamington Spa

Postcode: CV31 2NB

Client Details

Client Address:

Mr Singh
75 Ashford Gardens
Leamington Spa

Postcode: CV31 2NB

Appliance Details

CO/CO2 Ratio:

0.0004

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.2 %

CO Reading:

33 ppm

Boiler Make:

Glow worm

Boiler Model:

Ultracom 30cxi

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

boiler has no filter

Spares Required

advised landlord

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of Arrival:

11:00 am

Gas ID Number

5545563

Time of Departure:

11:00 am

Telephone Number

07961768920

Report Issued By Name:

Andrew King-Page

Signature:



Date:

Thu-19-Sept-2024

Report Received By Name:

Signature:

Date:

Thu-19-Sept-2024