

Installation DetailsInstallation
Address:Ling Cheung
14 Wheathill Close
Leamington Spa

Postcode: CV32 6PL

Client DetailsClient
Address:Ling Cheung
14 Wheathill Close
Leamington Spa

Postcode: CV32 6PL

Appliance DetailsCO/CO2
Ratio:

Service: YES

Breakdown: N/A

CO2
Reading:

7.5 %

CO Reading: 35 ppm

Boiler Make:

Vaillant

Boiler Model:

Thermocompact Vu GB

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks**Satisfactory**

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks**Satisfactory**

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations**Satisfactory**

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

pressure relief valve travels upwards, this is a safety hazard

Spares Required

boiler is over 25 years old and showing signs of age related degradation.

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

10:15 am

Gas ID Number

5545563

Time of

Departure:

10:15 am

Telephone Number

07961768920

Report Issued By

Name: Andrew King-Page

Signature:



Date:

Wed-14-Aug-2024

Report Received By

Name:

Signature:

Date:

Wed-14-Aug-2024