

# Gas Service/Breakdown Record

Certificate Ref.

20 Shrerres Dyche 2024

Certificate No 20 Shrerres Dyche 202

**Installation Details**Installation  
Address:Mr A Biss  
20 Shrerres Dyche  
Warwick

Postcode: CV34 6BX

**Client Details**Client  
Address:Mr A Biss  
20 Shrerres Dyche  
Warwick

Postcode: CV34 6BX

**Appliance Details**CO/CO2  
Ratio:

0.0006

Service:

0.0006

Breakdown:

N/A

CO2

Reading:

9.5 %

CO Reading:

58 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 24 RI HE

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

| Preliminary Checks                                     | Satisfactory | YES | NO | NA |
|--------------------------------------------------------|--------------|-----|----|----|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES          |     |    |    |
| Ventilation Size/H-L                                   | YES          |     |    |    |
| Water/Fuel - Sound                                     | YES          |     |    |    |
| Electrically Fused                                     | YES          |     |    |    |
| Correct Valving Arrangement                            | YES          |     |    |    |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES          |     |    |    |
| Boiler/Plant room Clean & Clear                        | YES          |     |    |    |
| Service Checks                                         | Satisfactory |     |    |    |
| Heat Exchanger                                         | YES          |     |    |    |
| Ignition                                               | YES          |     |    |    |
| Gas Valve                                              | YES          |     |    |    |
| Fan                                                    | YES          |     |    |    |
| Safety Device                                          | YES          |     |    |    |
| Control Box                                            | YES          |     |    |    |
| Burner & Pilot                                         | YES          |     |    |    |
| Fuel Pressure & Type                                   | YES          |     |    |    |
| Service Operations                                     | Satisfactory |     |    |    |
| Burner Washed & Clean                                  |              |     |    |    |
| Pilot Assembly Cleaned & Adjusted                      |              |     |    |    |
| Ignition System Cleaned & Adjusted                     |              |     |    |    |
| Burner Fan & Airways Cleaned                           |              |     |    |    |
| Heat Exchanger/Flueways Clean & Clear                  |              |     |    | NA |
| Fuel & Electrical Supply Connected & Sound             | YES          |     |    |    |
| Interlocks in Place                                    |              |     |    |    |

**Additional Notes**

serviced boiler

**Spares Required**

none

**Engineers Details**

Trading Title:

Coventry Gas Services Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of  
Arrival:

09:41 am

Gas ID Number

5545563

Time of

Departure:

09:41 am

Telephone Number

07961768920

Report Issued By

Name: Andrew King-Page

Signature:



Date:

Mon-22-Jul-2024

Report Received By

Name:

Signature:

Date:

Mon-22-Jul-2024