

Gas Service/Breakdown Record

Certificate Ref.

24 Ashtree Close Nuneaton CV11 6

Certificate No 24 Ashtree Close Nun

Installation Details

Installation Address:	Martin Blue 24 Ashtree Close Nuneaton	Client Address:	Martin Blue 24 Ashtree Close Nuneaton
	Postcode: CV11 6WT		Postcode: CV11 6WT

Client Details**Appliance Details**

CO/CO2 Ratio:	0.0016	Service:	YES	Breakdown:	N/A	CO2 Reading:	8.9 %	CO Reading:	144 ppm
Boiler Make:	Ideal	Boiler Model:	Logic Combi ESP1 35	Boiler Serial No:					
Appliance Make:		Appliance Model:		Appliance Serial No:					

Preliminary Checks

Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory	YES	NO	NA
Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory	YES	NO	NA
Burner Washed & Clean		NO	
Pilot Assembly Cleaned & Adjusted		NO	
Ignition System Cleaned & Adjusted		NO	
Burner Fan & Airways Cleaned		NO	
Heat Exchanger/Flueways Clean & Clear		NO	
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

serviced boiler and cleaned condense trap

Spares Required

none

Engineers Details

Trading Title:	Coventry Gas Services Ltd 47 Alspath Road Meriden	Gas Safe Number	927997	Time of Arrival:	09:44 am
	Postcode: CV7 7LU	Gas ID Number	5545563	Time of Departure:	09:44 am
		Telephone Number	07961768920		

Report Issued By Name:	Andrew King-Page	Signature:		Date:	Mon-15-Apr-2024
Report Received By Name:		Signature:		Date:	Mon-15-Apr-2024