

Gas Service/Breakdown Record

Certificate Ref.

9 Claypitts Boulevard Warwick CV34

Certificate No 9 Claypitts Boulevard

Installation Details

Installation Address: Claire Parfitt
9 Claypitts Boulevard Warwick CV34 6HQ
9 Claypitts Boulevard Warwick CV34 6HQ
9 Claypitts Boulevard Warwick CV34 6HQ
Postcode:

Client Details

Client Address: Claire Parfitt
9 Claypitts Boulevard Warwick CV34 6HQ
9 Claypitts Boulevard Warwick CV34 6HQ
9 Claypitts Boulevard Warwick CV34 6HQ
Postcode:

Appliance DetailsCO/CO2
Ratio:

0.0003

Service:

0.0003

Breakdown:

N/A

CO2

Reading:

9.0 %

CO Reading:

29 ppm

Boiler Make:

Boiler Model:

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks**Satisfactory****YES****NO****NA**

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks**Satisfactory**

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations**Satisfactory**

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned condense trap

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

10:01 am

Gas ID Number

5545563

Time of

Departure:

10:01 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Fri-12-Apr-2024

Report Received By

Name:

Signature:

Date:

Fri-12-Apr-2024