

Gas Service/Breakdown Record

Certificate Ref.

17 North Villers Street

Certificate No 17 North Villers Street

Installation Details

Installation Address: Nirmal K Panesar
17 N Villiers St
Leamington Spa Royal Leamington Spa
Postcode: CV32 5XZ

Client Details

Client Address: Nirmal K Panesar
17 N Villiers St
Leamington Spa Royal Leamington Spa
Postcode: CV32 5XZ

Appliance Details

CO/CO2 Ratio: 0.0006 Service: YES Breakdown: N/A CO2 Reading: 8.8 % CO Reading: 55 ppm

Boiler Make: Vaillant Boiler Model: Ecotec Plus 838 Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory	YES	NO	NA
Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory	YES	NO	NA
Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

cleaned filter and condense trap, replaced burner chamber seal

Spares Required

none

Engineers Details

Trading Title:
Postcode:

Gas Safe Number
Gas ID Number
Telephone Number
Time of Arrival: 11:02 am
Time of Departure: 11:02 am

Report Issued By Name:
Signature:
Date: Thu-14-Mar-2024
Report Received By Name:
Signature:
Date: Thu-14-Mar-2024