

Gas Service/Breakdown Record

Certificate Ref.

20 Kings Road 1

Certificate No 20 Kings Road 1

Installation Details

Installation Address: 20 Kings Road Stockland Green Birmingham B23 7JS
20 Kings Road Stockland Green Birmingham B23 7JS
20 Kings Road Stockland Green Birmingham B23 7JS
20 Kings Road Stockland Green Birmingham B23 7JS
Postcode:

Client Details

Client Address: Bal Forwell
44 Glendon Road
Birmingham
West Midlands
Postcode: B23 5HG

Appliance Details

CO/CO2 Ratio: 0.0007 Service: YES Breakdown: N/A CO2 Reading: 9.9 % CO Reading: 55 ppm

Boiler Make: Ideal Boiler Model: ISAR HE30 Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned condense trap and filter

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 927997 Time of Arrival: 02:00 pm
Gas ID Number 5545563 Time of Departure: 02:00 pm
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Wed-14-Feb-2024
Report Received By Name: Signature: Date: Wed-14-Feb-2024