

# Gas Service/Breakdown Record

Certificate Ref.

Lps 3 4

Certificate No Lps 3 4

**Installation Details**

Installation Address: LPS  
Clifford House  
Montague Road  
Warwick  
Postcode: CV34 5LW

**Client Details**

Client Address: LPS  
Clifford House  
Montague Road  
Warwick  
Postcode: CV34 5LW

**Appliance Details**

CO/CO2 Ratio: 0.0010 Service: YES Breakdown: N/A CO2 Reading: 9.7 % CO Reading: 97 ppm

Boiler Make: Worcester Boiler Model: Greenstar 38CDi Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

**Preliminary Checks**

**Satisfactory** YES NO NA

|                                                        |     |  |  |
|--------------------------------------------------------|-----|--|--|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES |  |  |
| Ventilation Size/H-L                                   | YES |  |  |
| Water/Fuel - Sound                                     | YES |  |  |
| Electrically Fused                                     | YES |  |  |
| Correct Valving Arrangement                            | YES |  |  |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |  |  |
| Boiler/Plant room Clean & Clear                        | YES |  |  |

**Service Checks**

**Satisfactory**

|                      |     |  |  |
|----------------------|-----|--|--|
| Heat Exchanger       | YES |  |  |
| Ignition             | YES |  |  |
| Gas Valve            | YES |  |  |
| Fan                  | YES |  |  |
| Safety Device        | YES |  |  |
| Control Box          | YES |  |  |
| Burner & Pilot       | YES |  |  |
| Fuel Pressure & Type | YES |  |  |

**Service Operations**

**Satisfactory**

|                                            |     |  |    |
|--------------------------------------------|-----|--|----|
| Burner Washed & Clean                      |     |  |    |
| Pilot Assembly Cleaned & Adjusted          |     |  |    |
| Ignition System Cleaned & Adjusted         |     |  |    |
| Burner Fan & Airways Cleaned               |     |  |    |
| Heat Exchanger/Flueways Clean & Clear      |     |  | NA |
| Fuel & Electrical Supply Connected & Sound | YES |  |    |
| Interlocks in Place                        |     |  |    |

**Additional Notes**

cleaned condense trap

**Spares Required**

none

**Engineers Details**

Trading Title: Coventry Gas Services Ltd  
47 Alspath Road  
Meriden  
Postcode: CV7 7LU

Gas Safe Number 927997 Time of Arrival: 09:44 am  
Gas ID Number 5545563 Time of Departure: 09:44 am  
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Wed-31-Jan-2024

Report Received By Name: Signature: Date: Wed-31-Jan-2024