

Gas Service/Breakdown Record

Certificate Ref.

37 Kerswell Drive Solihull B90 4PE

Certificate No 37 Kerswell Drive Soli

Installation Details

Installation Address: Helen Yates
37 Kerswell Drive
Solihull

Postcode: B90 4PE

Client Details

Client Address: Helen Yates
37 Kerswell Drive
Solihull

Postcode: B90 4PE

Appliance DetailsCO/CO2
Ratio:

0.0004

Service:

YES

Breakdown:

N/A

CO2

Reading:

8.8 %

CO Reading:

34 ppm

Boiler Make: Worcester Boiler Model: Greenstar 25Si Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks**Satisfactory****YES****NO****NA**

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks**Satisfactory**

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations**Satisfactory**

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

cleaned condense trap and magnetic filter

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

09:23 am

Gas ID Number

5545563

Time of

Departure:

09:23 am

Telephone Number

07961768920

Report Issued By Name: Andrew King-Page

Signature:

Date:

Thu-11-Jan-2024

Report Received By Name:

Signature:

Date:

Thu-11-Jan-2024