

Gas Service/Breakdown Record

Certificate Ref.

2 Pentland Crown Place 5

Certificate No 2 Pentland Crown Pla

Installation DetailsInstallation
Address:Hannah Elcome
2 pentland crown place
Leamington Spa

Postcode: CV33 9UH

Client DetailsClient
Address:Hannah Elcome
2 pentland crown place
Leamington Spa

Postcode: CV33 9UH

Appliance DetailsCO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2

Reading:

8.9 %

CO Reading:

41 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 30 Si

Boiler Serial No:

83706580007227733600

Appliance Make:

Worcester

Appliance Model:

Greenstar 30 Si

Appliance Serial No:

83706580007227733600

Preliminary Checks**Satisfactory****YES****NO****NA**

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks**Satisfactory**

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations**Satisfactory**

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

none

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

10:31 am

Gas ID Number

5545563

Time of

Departure:

10:31 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Tue-09-Jan-2024

Report Received By

Name:

Andrew King-Page

Signature:



Date:

Tue-09-Jan-2024