

Gas Service/Breakdown Record

Certificate Ref.

29 Edward Road Coventry CV6 2G

Certificate No 29 Edward Road Cove

Installation Details

Installation Address: Stephen Martin
29 Edward Road
Keresley
Coventry
Postcode: CV6 2GS

Client Details

Client Address: Stephen Martin
29 Edward Road
Keresley
Coventry
Postcode: CV6 2GS

Appliance Details

CO/CO2 Ratio: 0.0016 Service: YES Breakdown: N/A CO2 Reading: 9.1 % CO Reading: 143 ppm

Boiler Make: Baxi Boiler Model: 830 Combi Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned condense trap and filter

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number: 927997 Time of Arrival: 12:39 pm
Gas ID Number: 5545563 Time of Departure: 12:39 pm
Telephone Number: 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Mon-08-Jan-2024
Report Received By Name: Signature: Date: Mon-08-Jan-2024