

Gas Service/Breakdown Record

Certificate Ref.

46 Greyfort Crescent

Certificate No 46 Greyfort Crescent

Installation Details

Installation Address: Stuart Paul
46 Greyfort Crescent
Solihull

Postcode: B92 8DW

Client Details

Client Address: Stuart Paul
46 Greyfort Crescent
Solihull

Postcode: B92 8DW

Appliance Details

CO/CO2 Ratio:

0.0011

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.1 %

CO Reading:

90 ppm

Boiler Make: Worcester Boiler Model: 24i JUNIOR RSF Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

plate heat exchanger partially blocked, flow pipe isolator leaking, cleaned condensate trap

Spares Required

New plate heat exchanger and flow pipe isolator

Engineers Details

Trading Title: Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number: 927997 Time of Arrival: 10:38 am
Gas ID Number: 5545563 Time of Departure: 10:38 am
Telephone Number: 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Thu-17-Aug-2023

Report Received By Name: Signature: Date: Thu-17-Aug-2023