

Gas Service/Breakdown Record

Certificate Ref.

20 Sheres Dyche 1

Certificate No 20 Sheres Dyche 1

Installation Details

Installation Address:

Mr A Biss
20 Sheres Dyche
Warwick

Postcode: CV34 6BX

Client Details

Client Address:

Mr A Biss
20 Sheres Dyche
Warwick

Postcode: CV34 6BX

Appliance Details

CO/CO2 Ratio:

0.0007

Service:

0.0007

Breakdown:

N/A

CO2 Reading:

8.5 %

CO Reading:

60 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 24 RI HE

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

served boiler

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of Arrival:

10:30 am

Gas ID Number

5545563

Time of Departure:

10:30 am

Telephone Number

07961768920

Report Issued By Name:

Andrew King-Page

Signature:



Date:

Fri-04-Aug-2023

Report Received By Name:

Signature:

Date:

Fri-04-Aug-2023