

Gas Service/Breakdown Record

Certificate Ref.

7 Home Close Coventry CV8 3JD

Certificate No 7 Home Close Covent

Installation Details

Installation Address: Kathryn Taylor
7 Home Close
Coventry
Postcode: CV8 3JD

Client Details

Client Address: Kathryn Taylor
7 Home Close
Coventry
Postcode: CV8 3JD

Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: N/A CO2 Reading: 45 % CO Reading: 9.0 ppm
Boiler Make: Worcester Boiler Model: Greenstar 30CDI system Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted	YES			
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear	YES			
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

Auto air vent leaking, expansion vessel ruptured, signs of external leaks to 2 port valve and auto bypass

Spares Required

auto air vent, expansion vessel, leak sealer in system

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 09:57 am
Gas ID Number 4464997 Time of Departure: 09:57 am
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Thu-22-Jun-2023
Report Received By Name: Signature: Date: Thu-22-Jun-2023