

Gas Service/Breakdown Record

Certificate Ref.

21 Gould Road Hampton Magna W

Certificate No 21 Gould Road Hamp

Installation Details

Installation Address: Peter Kain
21 Gould Road
Hampton Magna
Warwick
Postcode: CV358TU

Client Details

Client Address: Peter Kain
21 Gould Road
Hampton Magna
Warwick
Postcode: CV358TU

Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: N/A CO2 Reading: 9.4 % CO Reading: 47 ppm

Boiler Make: Potterton Boiler Model: PROMAX COMBI 28 HE PLUS Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean	YES			
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear	YES			
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

boiler has been leaking from top of main heat exchanger, hot water thermistor had been leaking, auto air vent has been leaking, spark generator generating spark outside boiler

Spares Required

main heat exchanger seal pack, spark electrode kit, domestic hot water thermistor

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 10:06 am
Gas ID Number: 4464997 Time of Departure: 10:06 am
Telephone Number: 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Tue-16-May-2023
Report Received By Name: Signature: Date: Tue-16-May-2023