

Gas Service/Breakdown Record

Certificate Ref.

4 Haywood 1

Certificate No 4 Haywood 1

Installation Details

Installation Address: David Williams
4 Haywood Close
Hampton Magna

Postcode: CV35 8TJ

Client Details

Client Address: David Williams
4 Haywood Close
Hampton Magna

Postcode: CV35 8TJ

Appliance Details

CO/CO2 Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.4 %

CO Reading:

47 ppm

Boiler Make:

Baxi

Boiler Model:

830 Combi

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned condense trap and filter

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

10:33 am

Gas ID Number

4464997

Time of Departure:

10:33 am

Telephone Number

07961768920

Report Issued By Name:

Andrew King-Page

Signature:



Date:

Tue-16-May-2023

Report Received By Name:

Signature:

Date:

Tue-16-May-2023