

Gas Service/Breakdown Record

Certificate Ref.

24 Ashtree Close Nuneaton CV11 6

Certificate No 24 Ashtree Close Nun

Installation Details

Installation Address: Martin Blue
24 Ashtree Close
Nuneaton

Postcode: CV11 6WT

Client Details

Client Address: Martin Blue
24 Ashtree Close
Nuneaton

Postcode: CV11 6WT

Appliance Details

CO/CO2 Ratio: 0.0010 Service: YES Breakdown: N/A CO2 Reading: 9.5 % CO Reading: 95 ppm

Boiler Make: Ideal Boiler Model: Logic Combi ESP1 35 Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory YES NO NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean		NO	
Pilot Assembly Cleaned & Adjusted		NO	
Ignition System Cleaned & Adjusted		NO	
Burner Fan & Airways Cleaned		NO	
Heat Exchanger/Flueways Clean & Clear		NO	
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

serviced boiler and cleaned condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 10:12 am

Gas ID Number 4464997 Time of Departure: 10:12 am

Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Tue-09-May-2023

Report Received By Name: Signature: Date: Tue-09-May-2023