

Gas Service/Breakdown Record

Certificate Ref.

2 Pentland Crown Pace 4

Certificate No 2 Pentland Crown Pac

Installation Details

Installation Address:	Hannah Elcome 2 pentland crown place Leamington Spa	Client Address:	Hannah Elcome 2 pentland crown place Leamington Spa
	Postcode: CV33 9UH		Postcode: CV33 9UH

Client Details

Appliance Details

CO/CO2 Ratio:	0.0006	Service:	YES	Breakdown:	N/A	CO2 Reading:	9.5 %	CO Reading:	50 ppm
Boiler Make:	Worcester	Boiler Model:	Greenstar 30 Si	Boiler Serial No:	83706580007227733600				
Appliance Make:	Worcester	Appliance Model:	Greenstar 30 Si	Appliance Serial No:	83706580007227733600				

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

none

Spares Required

none

Engineers Details

Trading Title:	Coventry Gas Ltd 47 Alspath Road Meriden	Gas Safe Number	526645	Time of Arrival:	10:15 am
	Postcode: CV7 7LU	Gas ID Number	4464997	Time of Departure:	10:15 am
		Telephone Number	07961768920		
Report Issued By Name:	Andrew King-Page	Signature:		Date:	Mon-16-Jan-2023
Report Received By Name:	Andrew King-Page	Signature:		Date:	Mon-16-Jan-2023